

Date : 08/27/2025  
Project No : 2021C060  
Client Company : Pulte Group  
Arrival Time : 08/27/2025 09:00  
Onsite Hours : 01:30

ASEC Report ID : 84835  
Name of the Project : Suncity - Peachtree  
Project Location : Griffin, GA  
Weather : Sunny  
Departure Time : 08/27/2025 10:30  
ASEC Technician Name : Sean Willett

On the above date, our representative was onsite was requested by the contractor for a footing inspection of lot #149 pod #14.

Our representative inspected the site, and probe rodged the footing and found a low compaction area located on the front left corner of the building pad (as displayed in drawing). This area was recommended to be excavated approx. 2ft deep. This area was flagged with white flags approx. 3ft to 4ft in each direction of the footing. The rest of the footing around the building pad showed proper compaction.

The site is properly prepped for concrete pour.



white flagged low compaction area



DCP results and low compaction drawing



lot 149 pod 14



probe test low compaction

Date : 08/27/2025  
Project No : 2021C060  
Client Company : Pulte Group  
Arrival Time : 08/27/2025 09:00  
Onsite Hours : 01:30

ASEC Report ID : 84835  
Name of the Project : Suncity - Peachtree  
Project Location : Griffin, GA  
Weather : Sunny  
Departure Time : 08/27/2025 10:30  
ASEC Technician Name : Sean Willett



probe test low compaction



DCP testing

*Kenneth Mosman*

**Kenneth Mosman**

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.