

Date : 10/17/2024
Project No : 2023C180
Client Company : Artisan Communities
Arrival Time : 10/17/2024 10:00
Onsite Hours : 06:00

ASEC Report ID : 71461
Name of the Project : Lakeside Sub. - Lovers Lane, Calhoun
Project Location : Calhoun
Weather :
Departure Time : 10/17/2024 16:00
ASEC Technician Name : Solomon Cherie

Our AS Engineering & Consulting (ASEC) representative arrived on site to observe field activities. The following tasks were performed:

Placement of fill for the amenities area, including the tennis courts, pool area and clubhouse was completed today (to finished grade).

Compaction was completed with final testing performed using a proof-roll with a tandem-axled dump truck to verify subgrade stability. No severe pumping and/or rutting was observed during proof-rolling.



Clubhouse and pool area



Tennis court under pucking

Kenneth Mosman

Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.