

Date : 09/05/2024  
 Project No : 2023C180  
 Client Company : Artisan Communities  
 Arrival Time : 09/05/2024 08:00  
 Onsite Hours :

ASEC Report ID : 69510  
 Name of the Project : Lakeside Sub. - Lovers Lane, Calhoun  
 Project Location : Calhoun  
 Weather : Cloudy  
 Departure Time :  
 ASEC Technician Name : Solomon Cherie

Test Date	Test Number	Moisture Content (%)	Dry Density (pcf)	Proctor Number	Max. Dry Density (pcf)	Optimum Moisture (%)	Compaction (%)	Specified Compaction (%)	ASTM Test Method	Pass/Fail
09/06/2024	1	16.3	98.0	P-01	97.0	19.1	101.0	95	D6938	Pass
Location : Sewer line b/n 10.1 & 10.3, Elv/Depth :6 inches below finished grade Comment : Compaction is excellent. Tested By : Solomon Cherie Gauge Serial No. : 30942										

**Remark:** Test performed in general accordance with signed referenced ASTM Method.



**Kenneth Mosman**

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

Date : 09/05/2024  
Project No : 2023C180  
Client Company : Artisan Communities  
Arrival Time : 09/05/2024 08:00  
Onsite Hours :

ASEC Report ID : 69510  
Name of the Project : Lakeside Sub. - Lovers Lane, Calhoun  
Project Location : Calhoun  
Weather : Cloudy  
Departure Time :  
ASEC Technician Name : Solomon Cherie

---

**PROCTOR DATA SUMMARY**

TEST DATE	PROCTOR ID	MAX DRY DENSITY (pcf)	OPTIMUM MOISTURE (%)	PROCTOR TYPE	SOIL DESCRIPTION
	P-01	97.0	19.1	Standard	Light Tan Sandy Clay
	P-02	91.6	25.6	Standard	Yellow Brown Silty Clay