

Date : 09/11/2024
 Project No : 2023C180
 Client Company : Artisan Communities
 Arrival Time : 09/11/2024 08:00
 Onsite Hours :

ASEC Report ID : 69863
 Name of the Project : Lakeside Sub. - Lovers Lane, Calhoun
 Project Location : Calhoun
 Weather :
 Departure Time :
 ASEC Technician Name : Solomon Cherie

Test Date	Test Number	Moisture Content (%)	Dry Density (pcf)	Proctor Number	Max. Dry Density (pcf)	Optimum Moisture (%)	Compaction (%)	Specified Compaction (%)	ASTM Test Method	Pass/Fail
09/12/2024	1	18.1	94.2	P-01	97.0	19.1	97.1	95	D6938	Pass
Location : Lots #125-131, Elv/Depth :2 feet below finished grade										
Comment :										
Tested By : Solomon Cherie Gauge Serial No. : 30942										

Remark: Test performed in general accordance with signaturred referenced ASTM Method.



Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

Date : 09/11/2024
Project No : 2023C180
Client Company : Artisan Communities
Arrival Time : 09/11/2024 08:00
Onsite Hours :

ASEC Report ID : 69863
Name of the Project : Lakeside Sub. - Lovers Lane, Calhoun
Project Location : Calhoun
Weather :
Departure Time :
ASEC Technician Name : Solomon Cherie

PROCTOR DATA SUMMARY

TEST DATE	PROCTOR ID	MAX DRY DENSITY (pcf)	OPTIMUM MOISTURE (%)	PROCTOR TYPE	SOIL DESCRIPTION
	P-01	97.0	19.1	Standard	Light Tan Sandy Clay
	P-02	91.6	25.6	Standard	Yellow Brown Silty Clay