

Date : 05/15/2026
Project No : 2023C186
Client Company : CWM
Arrival Time : 05/15/2026 7:00
Onsite Hours : 07:00

ASEC Report ID : 94494
Name of the Project : Old Alabama Road (Roadway Testing
Only)
Project Location : Cartersville
Weather : Clear and sunny
Departure Time : 05/15/2026 14:00
ASEC Technician Name : Narayana Ganesh Undavalli

Location(S):

Testing: 0 Set of concrete specimens (per set) were cast during the cast-in-place concrete pour at the above referenced location, in accordance with ASTM C31. The specimen will remain on site for the initial 24-48 hrs curing.

Compliance: Field placement of concrete appeared to be in general accordance with the project specifications (i.e., slump, temperature, etc) (refer to remarks below)
Deviations and/or noncompliances were noted during the field placement (refer to remarks below)

Specimen Pick Up: 0 Sets of concrete specimens/ specimen per set were picked up & transported to AS Engineering and Consulting LLC (ASEC) for curing and testing in accordance with ASTM C39, C670/1231

Field Curing: Specimen were stored for the initial 24 hours
 Near the poured structure
 In an insulated curing box
 Other

Remarks: Test 1 - 8:55 AM Amb temp - 47 Concrete temp - 64 Air - 4.4 Slump - 2 Unit wt - 149.2.

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.