

Date : 08/01/2025  
Project No : 2023C195  
Client Company : Toll Bros. Inc.  
Arrival Time : 11:30  
Onsite Hours : 05:15

ASEC Report ID : 83905  
Name of the Project : Kimbal Bridge Tract  
Project Location : Alpharetta  
Weather :  
Departure Time : 16:45  
ASEC Technician Name :

- 
- I and Bal went to the project site to do DCP. We figure out it was 4 lots that is going to have dcp tests.
  - I did the dcp tests for Lot#10 and Lot#11.
  - The dcp tests were done manually at four corners for each Lots.
  - Two tests were encountered rock and an offset of 2' far were done,
  - The remaining tests were done to 4 feet.
  - All of them were showing 8 and above blows of dcp
  - The result finally was analuazed and synthesized and presumed to pass the test.

*Kenneth Mosman*

**Kenneth Mosman**

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.