

Date : 08/01/2025
Project No : 2023C195
Client Company : Toll Bros. Inc.
Arrival Time : 08/01/2025 11:30
Onsite Hours : 05:15

ASEC Report ID : 83902
Name of the Project : Kimbal Bridge Tract
Project Location : Alpharetta
Weather :
Departure Time : 08/01/2025 16:45
ASEC Technician Name : Solomon Cherie

-
- I and Bal went to the project site to do DCP. We figure out it was 4 lots that is going to have dcp tests.
 - I did the dcp tests for Lot#10 and Lot#11.
 - The dcp tests were done manually at four corners for each Lots.
 - Two tests were encountered rock and an offset of 2' far were done,
 - The remaining tests were done to 4 feet.
 - All of them were showing 8 and above blows of dcp
 - The result finally was analuazed and synthesized and presumed to pass the test.



Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.