

Date : 10/22/2024
 Project No : 2024C116
 Client Company : Peeples Owner, LLC
 Arrival Time : 10/22/2024 08:30
 Onsite Hours : 08:30

ASEC Report ID : 71958
 Name of the Project : Peeples Valley Rd, Overlook at Pettit
 Project Location : Cartersville
 Weather : Sunny
 Departure Time : 10/22/2024 17:00
 ASEC Technician Name : Fawad Shagiwal

Test Date	Test Number	Moisture Content (%)	Dry Density (pcf)	Proctor Number	Max. Dry Density (pcf)	Optimum Moisture (%)	Compaction (%)	Specified Compaction (%)	ASTM Test Method	Pass/Fail
10/22/2024	1	17.3	103.7	P-01	108.9	17.9	95.2	95	D6938	Pass
Location : Sewer line trench, Elv/Depth :3 feet below finished grade										
Comment :										
Tested By : Fawad Shagiwal Gauge Serial No. : 29588										
10/22/2024	2	17.0	106.6	P-01	108.9	17.9	97.9	95	D6938	Pass
Location : Sewer line trench, Elv/Depth :3 feet below finished grade										
Comment :										
Tested By : Fawad Shagiwal Gauge Serial No. : 29588										
10/22/2024	3	18.4	107.6	P-01	108.9	17.9	98.8	95	D6938	Pass
Location : Sewer line trench, Elv/Depth :3 feet below finished grade										
Comment :										
Tested By : Fawad Shagiwal Gauge Serial No. : 29588										
10/22/2024	4	17.6	102.1	P-02	107.4	20.2	95.1	95	D6938	Pass
Location : Sewer line trench, Elv/Depth :3 feet below finished grade										
Comment :										
Tested By : Fawad Shagiwal Gauge Serial No. : 29588										

Remark: Test performed in general accordance with signed referenced ASTM Method.



Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

Date : 10/22/2024
Project No : 2024C116
Client Company : Peeples Owner, LLC
Arrival Time : 10/22/2024 08:30
Onsite Hours : 08:30

ASEC Report ID : 71958
Name of the Project : Peeples Valley Rd, Overlook at Pettit
Project Location : Cartersville
Weather : Sunny
Departure Time : 10/22/2024 17:00
ASEC Technician Name : Fawad Shagiwal

PROCTOR DATA SUMMARY

TEST DATE	PROCTOR ID	MAX DRY DENSITY (pcf)	OPTIMUM MOISTURE (%)	PROCTOR TYPE	SOIL DESCRIPTION
05/01/2024	P-01	108.9	17.9	Standard	Reddish Brown Sandy Clay
06/18/2024	P-02	107.4	20.2	Standard	Light brown Sandy SILT