

Date : 09/04/2024
 Project No : 2024C116
 Client Company : Peeples Owner, LLC
 Arrival Time : 09/04/2024 09:00
 Onsite Hours : 08:00

ASEC Report ID : 69479
 Name of the Project : Peeples Valley Rd, Overlook at Pettit
 Project Location : Cartersville
 Weather : Sunny
 Departure Time : 09/04/2024 17:00
 ASEC Technician Name : Fawad Shagiwal

Test Date	Test Number	Moisture Content (%)	Dry Density (pcf)	Proctor Number	Max. Dry Density (pcf)	Optimum Moisture (%)	Compaction (%)	Specified Compaction (%)	ASTM Test Method	Pass/Fail
09/04/2024	1	17.6	97.4	P-01	108.9	17.9	89.4	95	D6938	Fail
Location : Lot #89, Elv/Depth :2 feet below finished grade Comment : Recommended to contractor to recompact and retest this area. Tested By : Fawad Shagiwal Gauge Serial No. : 38069										
09/04/2024	2	17.9	122.2	P-01	108.9	17.9	95.1	95	D6938	Pass
Location : Lot #90, Elv/Depth :3 feet below finished grade Comment : Tested By : Fawad Shagiwal Gauge Serial No. : 38069										
09/04/2024	3	17.2	106.9	P-01	108.9	17.9	98.2	95	D6938	Pass
Location : Lot #91, Elv/Depth :3 feet below finished grade Comment : Tested By : Fawad Shagiwal Gauge Serial No. : 38069										
09/04/2024	4	17.6	96.3	P-01	108.9	17.9	88.4	95	D6938	Fail
Location : Lot #92, Elv/Depth :2.5 feet below finished grade Comment : Recommended to contractor to recompact and retest this area. Tested By : Fawad Shagiwal Gauge Serial No. : 38069										
09/04/2024	5	17.3	107.5	P-01	108.9	17.9	98.7	95	D6938	Pass
Location : Lot #93, Elv/Depth :2 feet below finished grade Comment : Tested By : Fawad Shagiwal Gauge Serial No. : 38069										

Remark: Test performed in general accordance with signaturred referenced ASTM Method.



Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

Date : 09/04/2024
Project No : 2024C116
Client Company : Peeples Owner, LLC
Arrival Time : 09/04/2024 09:00
Onsite Hours : 08:00

ASEC Report ID : 69479
Name of the Project : Peeples Valley Rd, Overlook at Pettit
Project Location : Cartersville
Weather : Sunny
Departure Time : 09/04/2024 17:00
ASEC Technician Name : Fawad Shagiwal

PROCTOR DATA SUMMARY

TEST DATE	PROCTOR ID	MAX DRY DENSITY (pcf)	OPTIMUM MOISTURE (%)	PROCTOR TYPE	SOIL DESCRIPTION
05/01/2024	P-01	108.9	17.9	Standard	Reddish Brown Sandy Clay
06/18/2024	P-02	107.4	20.2	Standard	Light brown Sandy SILT