

ASEC Report ID : 71311  
 Name of the Project : Reserve @ Gum Springs  
 Project Location : Jefferson  
 Weather : sunny  
 Departure Time : 10/09/2024 17:30  
 ASEC Technician Name : Aminullah Azimi

Date : 10/09/2024  
 Project No : 2024C168  
 Client Company : CCG  
 Arrival Time : 10/09/2024 12:00  
 Onsite Hours : 05:30

Test Date	Test Number	Moisture Content (%)	Dry Density (pcf)	Proctor Number	Max. Dry Density (pcf)	Optimum Moisture (%)	Compaction (%)	Specified Compaction (%)	ASTM Test Method	Pass/Fail
10/09/2024	157	23.0	98.2	26081	102.9	20.0	95.4	95	D2937	Pass
Location : Sewer trench, 11 feet west from MHSF2, Elv/Depth :1 foot below finished grade										
Comment :										
Tested By : Aminullah Azimi										
10/09/2024	158	19.8	102.5	26081	102.9	20.0	99.6	98	D2937	Pass
Location : Sewer trench, 12 feet SW from MHSF2, Elv/Depth :finished grade										
Comment :										
Tested By : Aminullah Azimi										
10/09/2024	159	19.0	101.3	26081	102.9	20.0	98.4	98	D2937	Pass
Location : Sewer trench, between MHB16 and MHB16.1, Elv/Depth :finished grade										
Comment :										
Tested By : Aminullah Azimi										

**Remark:** Test performed in general accordance with signatred referenced ASTM Method.



**Kenneth Mosman**

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

ASEC Report ID : 71311  
Name of the Project : Reserve @ Gum Springs  
Project Location : Jefferson  
Weather : sunny  
Departure Time : 10/09/2024 17:30  
ASEC Technician Name : Aminullah Azimi

Date : 10/09/2024  
Project No : 2024C168  
Client Company : CCG  
Arrival Time : 10/09/2024 12:00  
Onsite Hours : 05:30

**PROCTOR DATA SUMMARY**

TEST DATE	PROCTOR ID	MAX DRY DENSITY (pcf)	OPTIMUM MOISTURE (%)	PROCTOR TYPE	SOIL DESCRIPTION
07/01/2024	26081	102.9	20.0	Standard	Reddish Brown Sandy SILT
07/01/2024	26082	94.1	24.3	Standard	Brown Sandy SILT
07/01/2024	26083	102.0	22.1	Standard	Light Brown Sandy SILT
07/26/2024	26084	102.0	19.6	Standard	Brown Sandy SILT
07/26/2024	26085	92.0	25.3	Standard	Reddish-Brown Sandy SILT