

ASEC Report ID : 70850  
 Name of the Project : Reserve @ Gum Springs  
 Project Location : Jefferson  
 Weather : cloudy  
 Departure Time : 10/01/2024 18:30  
 ASEC Technician Name : Aminullah Azimi

Date : 10/01/2024  
 Project No : 2024C168  
 Client Company : CCG  
 Arrival Time : 10/01/2024 11:00  
 Onsite Hours : 07:30

Test Date	Test Number	Moisture Content (%)	Dry Density (pcf)	Proctor Number	Max. Dry Density (pcf)	Optimum Moisture (%)	Compaction (%)	Specified Compaction (%)	ASTM Test Method	Pass/Fail
10/01/2024	134	28.5	91.1	26082	94.1	24.3	96.8	95	D2937	Pass
Location : Sewer trench, 10 feet south of MHSL1, Elv/Depth :1 foot below finished grade										
Comment :										
Tested By : Aminullah Azimi										
10/01/2024	135	24.0	89.5	26082	94.1	24.3	95.1	95	D2937	Pass
Location : Sewer trench, 210 feet south of MHSL1, Elv/Depth :1 foot below finished grade										
Comment :										
Tested By : Aminullah Azimi										
10/01/2024	136	28.7	92.7	26082	94.1	24.3	98.5	95	D2937	Pass
Location : Storm water trench, 13 feet NE from MHA29, Elv/Depth :1 foot below finished grade										
Comment :										
Tested By : Aminullah Azimi										
10/01/2024	137	24.1	100.3	26081	102.9	20.0	97.5	95	D2937	Pass
Location : Storm water trench, 15 feet SW from MHA2.10, Elv/Depth :1.5 feet below finished grade										
Comment :										
Tested By : Aminullah Azimi										
10/01/2024	138	23.4	100.1	26081	102.9	20.0	97.3	95	D2937	Pass
Location : Storm water trench, between MHA2.10 and MHA2.11., Elv/Depth :0.5 foot below finished grade										
Comment :										
Tested By : Aminullah Azimi										
10/01/2024	139	23.9	98.3	26081	102.9	20.0	95.5	95	D2937	Pass
Location : Sewer trench, 10 feet SE from MHSF2, Elv/Depth :3 feet below finished grade										
Comment :										
Tested By : Aminullah Azimi										

**Remark:** Test performed in general accordance with signed referenced ASTM Method.

  
**Kenneth Mosman**

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

ASEC Report ID : 70850  
 Name of the Project : Reserve @ Gum Springs  
 Project Location : Jefferson  
 Weather : cloudy  
 Departure Time : 10/01/2024 18:30  
 ASEC Technician Name : Aminullah Azimi

Date : 10/01/2024  
 Project No : 2024C168  
 Client Company : CCG  
 Arrival Time : 10/01/2024 11:00  
 Onsite Hours : 07:30

**PROCTOR DATA SUMMARY**

TEST DATE	PROCTOR ID	MAX DRY DENSITY (pcf)	OPTIMUM MOISTURE (%)	PROCTOR TYPE	SOIL DESCRIPTION
07/01/2024	26081	102.9	20.0	Standard	Reddish Brown Sandy SILT
07/01/2024	26082	94.1	24.3	Standard	Brown Sandy SILT
07/01/2024	26083	102.0	22.1	Standard	Light Brown Sandy SILT
07/26/2024	26084	102.0	19.6	Standard	Brown Sandy SILT
07/26/2024	26085	92.0	25.3	Standard	Reddish-Brown Sandy SILT