

ASEC Report ID : 72328
 Name of the Project : Reserve @ Gum Springs
 Project Location : Jefferson
 Weather : sunny
 Departure Time : 10/25/2024 16:30
 ASEC Technician Name : Aminullah Azimi

Date : 10/25/2024
 Project No : 2024C168
 Client Company : CCG
 Arrival Time : 10/25/2024 12:00
 Onsite Hours : 04:30

Test Date	Test Number	Moisture Content (%)	Dry Density (pcf)	Proctor Number	Max. Dry Density (pcf)	Optimum Moisture (%)	Compaction (%)	Specified Compaction (%)	ASTM Test Method	Pass/Fail
10/25/2024	226	21.9	98.0	26081	102.9	20.0	95.2	95	D6938	Pass
Location : Storm water trench, between MHC10 and MHC10.1, Elv/Depth :1 foot below finished grade										
Comment :										
Tested By : Aminullah Azimi Gauge Serial No. : 85759										
10/25/2024	227	26.7	90.4	26082	94.1	24.3	96.1	95	D6938	Pass
Location : Storm water trench, between MHC11 and MHC11.1, Elv/Depth :2 feet below finished grade										
Comment :										
Tested By : Aminullah Azimi Gauge Serial No. : 85759										
10/25/2024	228	27.1	90.6	26082	94.1	24.3	96.3	95	D6938	Pass
Location : Storm water trench, between MHC11 and MHC11.1, Elv/Depth :1 foot below finished grade										
Comment :										
Tested By : Aminullah Azimi Gauge Serial No. : 85759										
10/25/2024	229	26.9	90.1	26082	94.1	24.3	95.7	95	D6938	Pass
Location : Storm water trench, 30 feet SW from MHC11, Elv/Depth :2 feet below finished grade										
Comment :										
Tested By : Aminullah Azimi Gauge Serial No. : 85759										

Remark: Test performed in general accordance with signed referenced ASTM Method.

Kenneth Mosman
Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

ASEC Report ID : 72328
 Name of the Project : Reserve @ Gum Springs
 Project Location : Jefferson
 Weather : sunny
 Departure Time : 10/25/2024 16:30
 ASEC Technician Name : Aminullah Azimi

Date : 10/25/2024
 Project No : 2024C168
 Client Company : CCG
 Arrival Time : 10/25/2024 12:00
 Onsite Hours : 04:30

PROCTOR DATA SUMMARY

TEST DATE	PROCTOR ID	MAX DRY DENSITY (pcf)	OPTIMUM MOISTURE (%)	PROCTOR TYPE	SOIL DESCRIPTION
07/01/2024	26081	102.9	20.0	Standard	Reddish Brown Sandy SILT
07/01/2024	26082	94.1	24.3	Standard	Brown Sandy SILT
07/01/2024	26083	102.0	22.1	Standard	Light Brown Sandy SILT
07/26/2024	26084	102.0	19.6	Standard	Brown Sandy SILT
07/26/2024	26085	92.0	25.3	Standard	Reddish-Brown Sandy SILT