

ASEC Report ID : 72343
 Name of the Project : Reserve @ Gum Springs
 Project Location : Jefferson
 Weather : sunny
 Departure Time : 10/26/2024 14:00
 ASEC Technician Name : Aminullah Azimi

Date : 10/26/2024
 Project No : 2024C168
 Client Company : CCG
 Arrival Time : 10/26/2024 8:30
 Onsite Hours : 05:30

Test Date	Test Number	Moisture Content (%)	Dry Density (pcf)	Proctor Number	Max. Dry Density (pcf)	Optimum Moisture (%)	Compaction (%)	Specified Compaction (%)	ASTM Test Method	Pass/Fail
10/26/2024	230	19.1	92.8	26082	94.1	24.3	98.6	95	D6938	Pass
Location : Storm water trench, 15 feet NE from MHC12, Elv/Depth :1 foot below finished grade Comment : Moisture content was lower than specified moisture limit. Tested By : Aminullah Azimi Gauge Serial No. : 85759										
10/26/2024	231	25.4	90.4	26082	94.1	24.3	96.1	95	D6938	Pass
Location : Storm water trench, 12 feet NE from MHC13, Elv/Depth :1.5 feet below finished grade Comment : Tested By : Aminullah Azimi Gauge Serial No. : 85759										
10/26/2024	232	22.5	98.4	26081	102.9	20.0	95.6	95	D6938	Pass
Location : Storm water trench, 48 feet SW from MHC13, Elv/Depth :2.5 feet below finished grade Comment : Tested By : Aminullah Azimi Gauge Serial No. : 85759										

Remark: Test performed in general accordance with signatured referenced ASTM Method.



Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

ASEC Report ID : 72343
 Name of the Project : Reserve @ Gum Springs
 Project Location : Jefferson
 Weather : sunny
 Departure Time : 10/26/2024 14:00
 ASEC Technician Name : Aminullah Azimi

Date : 10/26/2024
 Project No : 2024C168
 Client Company : CCG
 Arrival Time : 10/26/2024 8:30
 Onsite Hours : 05:30

PROCTOR DATA SUMMARY

TEST DATE	PROCTOR ID	MAX DRY DENSITY (pcf)	OPTIMUM MOISTURE (%)	PROCTOR TYPE	SOIL DESCRIPTION
07/01/2024	26081	102.9	20.0	Standard	Reddish Brown Sandy SILT
07/01/2024	26082	94.1	24.3	Standard	Brown Sandy SILT
07/01/2024	26083	102.0	22.1	Standard	Light Brown Sandy SILT
07/26/2024	26084	102.0	19.6	Standard	Brown Sandy SILT
07/26/2024	26085	92.0	25.3	Standard	Reddish-Brown Sandy SILT