

ASEC Report ID : 73083
 Name of the Project : Reserve @ Gum Springs
 Project Location : Jefferson
 Weather : cloudy
 Departure Time : 11/07/2024 16:45
 ASEC Technician Name : Aminullah Azimi

Date : 11/07/2024
 Project No : 2024C168
 Client Company : CCG
 Arrival Time : 11/07/2024 8:15
 Onsite Hours : 08:30

Test Date	Test Number	Moisture Content (%)	Dry Density (pcf)	Proctor Number	Max. Dry Density (pcf)	Optimum Moisture (%)	Compaction (%)	Specified Compaction (%)	ASTM Test Method	Pass/Fail
11/07/2024	287	19.3	100.3	26081	102.9	20.0	97.5	95	D2937	Pass
Location : water line in front of Lot #117, Elv/Depth :finished grade										
Comment :										
Tested By : Aminullah Azimi										
11/07/2024	288	21.8	98.3	26081	102.9	20.0	95.5	95	D2937	Pass
Location : water line in front of Lot #117, Elv/Depth :finished grade										
Comment :										
Tested By : Aminullah Azimi										
11/07/2024	289	21.1	101.3	26081	102.9	20.0	98.4	95	D2937	Pass
Location : in front of greenbelt area , Elv/Depth :finished grade										
Comment :										
Tested By : Aminullah Azimi										
11/07/2024	290	20.9	99.9	26081	102.9	20.0	97.1	95	D2937	Pass
Location : water trench, in front of Lot #222, Elv/Depth :finished grade										
Comment :										
Tested By : Aminullah Azimi										
11/07/2024	291	22.9	102.0	26081	102.9	20.0	99.1	98	D6938	Pass
Location : roadway between Lots #103 and #128, Elv/Depth :finished grade										
Comment :										
Tested By : Aminullah Azimi Gauge Serial No. : 85759										
11/07/2024	292	19.0	100.9	26081	102.9	20.0	98.1	98	D6938	Pass
Location : roadway between Lots #107 and #124, Elv/Depth :finished grade										
Comment :										
Tested By : Aminullah Azimi Gauge Serial No. : 85759										
11/07/2024	293	26.5	93.5	26082	94.1	24.3	99.4	95	D6938	Pass
Location : roadway in front of Lot #111, Elv/Depth :finished grade										
Comment :										
Tested By : Aminullah Azimi Gauge Serial No. : 85759										
11/07/2024	294	20.1	101.1	26081	102.9	20.0	98.3	98	D6938	Pass
Location : roadway between Lots#115 and #123, Elv/Depth :finished grade										
Comment :										
Tested By : Aminullah Azimi Gauge Serial No. : 85759										
11/07/2024	295	24.5	93.7	26082	94.1	24.3	99.6	98	D6938	Pass
Location : roadway between Lots #117 and #121, Elv/Depth :finished grade										
Comment :										
Tested By : Aminullah Azimi Gauge Serial No. : 85759										
11/07/2024	296	21	101.7	26081	102.9	20.0	98.8	98	D6938	Pass
Location : roadway between Lots #150 and #119, Elv/Depth :finished grade										
Comment :										
Tested By : Aminullah Azimi Gauge Serial No. : 85759										

Remark: Test performed in general accordance with signatred referenced ASTM Method.

Date : 11/07/2024
Project No : 2024C168
Client Company : CCG
Arrival Time : 11/07/2024 8:15
Onsite Hours : 08:30

ASEC Report ID : 73083
Name of the Project : Reserve @ Gum Springs
Project Location : Jefferson
Weather : cloudy
Departure Time : 11/07/2024 16:45
ASEC Technician Name : Aminullah Azimi



Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

ASEC Report ID : 73083
 Name of the Project : Reserve @ Gum Springs
 Project Location : Jefferson
 Weather : cloudy
 Departure Time : 11/07/2024 16:45
 ASEC Technician Name : Aminullah Azimi

Date : 11/07/2024
 Project No : 2024C168
 Client Company : CCG
 Arrival Time : 11/07/2024 8:15
 Onsite Hours : 08:30

PROCTOR DATA SUMMARY

TEST DATE	PROCTOR ID	MAX DRY DENSITY (pcf)	OPTIMUM MOISTURE (%)	PROCTOR TYPE	SOIL DESCRIPTION
07/01/2024	26081	102.9	20.0	Standard	Reddish Brown Sandy SILT
07/01/2024	26082	94.1	24.3	Standard	Brown Sandy SILT
07/01/2024	26083	102.0	22.1	Standard	Light Brown Sandy SILT
07/26/2024	26084	102.0	19.6	Standard	Brown Sandy SILT
07/26/2024	26085	92.0	25.3	Standard	Reddish-Brown Sandy SILT
11/14/2024	26086	99.8	19.7	Standard	Brown Silty SAND