

Date : 01/14/2025
Project No : 2024C168
Client Company : Century Communities
Arrival Time : 01/14/2025 9:00
Onsite Hours : 08:00

ASEC Report ID : 75948
Name of the Project : Reserve @ Gum Springs
Project Location : Jefferson, Jackson County, Georgia
Weather : sunny
Departure Time : 01/14/2025 17:00
ASEC Technician Name : Aminullah Azimi

Quality Control Inspection and Testing Services Report

As requested, our AS Engineering and Consulting (ASEC) representative visited the site to provide quality control inspection and testing services. Visual observation techniques were employed to verify compliance with project drawings/specifications, applicable codes, and material submittals. The following observations were made on-site today:


1. Stabilization of Retaining Wall #1 Footing

- Observed between Station 0+95 and Station 1+27.
- The footing was muddy with groundwater present at the surface.
- The contractor addressed wet surficial soil issue by placing a 3-foot layer of riprap at the bottom, compacting using an excavator. Following this, a 1-foot layer of No. 57 stone was placed by the wall contractor.

2. Installation of Retaining Wall Blocks

- The placement of ride rock blocks was in progress.
- Geo-grid reinforcement was installed with every course of the wall.
- A 1-foot layer of No. 57 stone was utilized behind the blocks and within the wall cells.

Should you have any questions or concerns regarding the observations or recommendations in this report, please do not hesitate to contact us. We would be glad to discuss them further.



Date : 01/14/2025
Project No : 2024C168
Client Company : Century Communities
Arrival Time : 01/14/2025 9:00
Onsite Hours : 08:00

ASEC Report ID : 75948
Name of the Project : Reserve @ Gum Springs
Project Location : Jefferson, Jackson County, Georgia
Weather : sunny
Departure Time : 01/14/2025 17:00
ASEC Technician Name : Aminullah Azimi



Kenneth Mosman

Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.