

Date : 11/26/2024  
Project No : 2024C189  
Client Company : WSP  
Arrival Time : 11/26/2024 12:30  
Onsite Hours :

ASEC Report ID : 73575  
Name of the Project : Protovision PH II  
Project Location : Lithia Springs  
Weather : Rainy  
Departure Time :  
ASEC Technician Name : Solomon Cherie

---

**Location(S):**

**Testing:** 1 Set of concrete specimens (5 Cylinders per set) were cast during the cast-in-place concrete pour at the above referenced location, in accordance with ASTM C31. The cylinders will remain on site for the initial 24-48 hrs curing.

**Compliance:** ☒ Field placement of concrete appeared to be in general accordance with the project specifications (i.e., slump, temperature, etc) (refer to remarks below)  
☐ Deviations and/or noncompliances were noted during the field placement (refer to remarks below)

**Cylinders Pick Up:** 1 Sets of concrete cylinders/ 5 cylinders per set were picked up & transported to AS Engineering and Consulting LLC (ASEC) for curing and testing in accordance with ASTM C39, C670/1231

**Field Curing:** Cylinders were stored for the initial 24 hours  
☒ Near the poured structure  
☐ In an insulated curing box  
☐ Other

**Remarks:** This was the third test for truck number 13 at 117 yards. The test results were: Air=3.6% Slump=6.75"  
Temperature=64°F Unit weight=141.6 psi

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.