

Date : 10/28/2024  
 Project No : 2024C202  
 Client Company : CCG  
 Arrival Time : 10/28/2024 07:30  
 Onsite Hours :

ASEC Report ID : 72299  
 Name of the Project : Old Griffin Rd - Hawthorne Reserve  
 Project Location : Dallas  
 Weather :  
 Departure Time :  
 ASEC Technician Name : Solomon Cherie

Test Date	Test Number	Moisture Content (%)	Dry Density (pcf)	Proctor Number	Max. Dry Density (pcf)	Optimum Moisture (%)	Compaction (%)	Specified Compaction (%)	ASTM Test Method	Pass/Fail
10/28/2024	2	23.4	120.9	S-01	101.9	20.5	96.2	95	D6938	Pass
Location : Lot #76, Elv/Depth :3 feet below finished grade										
Comment :										
Tested By : Solomon Cherie Gauge Serial No. : 30942										

**Remark:** Test performed in general accordance with signed referenced ASTM Method.



**Kenneth Mosman**

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

Date : 10/28/2024  
Project No : 2024C202  
Client Company : CCG  
Arrival Time : 10/28/2024 07:30  
Onsite Hours :

ASEC Report ID : 72299  
Name of the Project : Old Griffin Rd - Hawthorne Reserve  
Project Location : Dallas  
Weather :  
Departure Time :  
ASEC Technician Name : Solomon Cherie

---

**PROCTOR DATA SUMMARY**

TEST DATE	PROCTOR ID	MAX DRY DENSITY (pcf)	OPTIMUM MOISTURE (%)	PROCTOR TYPE	SOIL DESCRIPTION
10/16/2024	S-01	101.9	20.5	Standard	Tan Clayey SILT
10/31/2024	S-02	97.2	24.9	Standard	Red Sandy CLAY