

Date : 12/20/2024
Project No : 2024C202
Client Company : CCG
Arrival Time : 12/20/2024 07:30
Onsite Hours :

ASEC Report ID : 74660
Name of the Project : Old Griffin Rd - Hawthorne Reserve
Project Location : Dallas
Weather : Sunny
Departure Time : 12/20/2024
ASEC Technician Name : Solomon Cherie

Location(S):

Testing: 1 Set of concrete specimens (7 Cylinders per set) were cast during the cast-in-place concrete pour at the above referenced location, in accordance with ASTM C31. The cylinders will remain on site for the initial 24-48 hrs curing.

Compliance: ☒ Field placement of concrete appeared to be in general accordance with the project specifications (i.e., slump, temperature, etc) (refer to remarks below)
☐ Deviations and/or noncompliances were noted during the field placement (refer to remarks below)

Cylinders Pick Up: 1 Sets of concrete cylinders/ 7 cylinders per set were picked up & transported to AS Engineering and Consulting LLC (ASEC) for curing and testing in accordance with ASTM C39, C670/1231

Field Curing: Cylinders were stored for the initial 24 hours
☐ Near the poured structure
☒ In an insulated curing box
☐ Other

Remarks: Our ASEC representative was on site to observe the placement of concrete for the detention pond wall footing. A total of 57 cubic yards of concrete was placed and one (1) set of seven (7) cylinders were cast. There was considerable delay between concrete truck arrivals.

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.