

Date : 11/26/2024
Project No : 2024C202
Client Company : CCG
Arrival Time : 11/26/2024 10:45
Onsite Hours : 02:00

ASEC Report ID : 73610
Name of the Project : Old Griffin Rd - Hawthorne Reserve
Project Location : Dallas
Weather : Partly cloudy
Departure Time : 11/26/2024 12:45
ASEC Technician Name : Solomon Cherie

Our AS Engineering & Consulting (ASEC) representative arrived on site to observe field activities. The following tasks were performed:

Observed the placement of fill/grading for Lot #73 and the access road today. Compaction tests were performed using a nuclear density gauge. Due to excessively high moisture contents, taken the first two tests, we recommend scarifying, aerating and recompaction of these wet soils. Results are attached in separate reports.

Please contact us if you have any questions regarding this report or of the density test results.



Picture showing how muddy is the site



Visible water patches here and there

Kenneth Mosman

Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.