

Date : 01/09/2025  
 Project No : 2024C202  
 Client Company : CCG  
 Arrival Time : 01/09/2025 07:45  
 Onsite Hours :

ASEC Report ID : 75199  
 Name of the Project : Old Griffin Rd - Hawthorne Reserve  
 Project Location : Dallas  
 Weather : Clear sky  
 Departure Time : 01/09/2025  
 ASEC Technician Name : Solomon Cherie

| Test Date  | Test Number | Moisture Content (%) | Dry Density (pcf) | Proctor Number | Max. Dry Density (pcf) | Optimum Moisture (%) | Compaction (%) | Specified Compaction (%) | ASTM Test Method | Pass/Fail |
|--|-------------|----------------------|-------------------|----------------|------------------------|----------------------|----------------|--------------------------|------------------|-----------|
| 01/09/2025   | 1           | 23.9                 | 95.7              | S-02           | 97.2                   | 24.9                 | 98.5           | 95                       | D6938            | Pass      |
| Location : Lot #27, Elv/Depth :15 feet below finished grade                          |             |                      |                   |                |                        |                      |                |                          |                  |           |
| Comment :  |             |                      |                   |                |                        |                      |                |                          |                  |           |
| Tested By : Solomon Cherie Gauge Serial No. : 30942                                  |             |                      |                   |                |                        |                      |                |                          |                  |           |
| 01/09/2025   | 2           | 25.4                 | 93.7              | S-02           | 97.2                   | 24.9                 | 96.4           | 95                       | D6938            | Pass      |
| Location : Lot #29, Elv/Depth :11 feet below finished grade                          |             |                      |                   |                |                        |                      |                |                          |                  |           |
| Comment :  |             |                      |                   |                |                        |                      |                |                          |                  |           |
| Tested By : Solomon Cherie Gauge Serial No. : 30942                                  |             |                      |                   |                |                        |                      |                |                          |                  |           |
| 01/09/2025   | 3           | 23.7                 | 95.3              | S-02           | 97.2                   | 24.9                 | 98.0           | 95                       | D6938            | Pass      |
| Location : Sewer line b/t manhole A12 and E1, Elv/Depth :2 foot below finished grade |             |                      |                   |                |                        |                      |                |                          |                  |           |
| Comment :  |             |                      |                   |                |                        |                      |                |                          |                  |           |
| Tested By : Solomon Cherie Gauge Serial No. : 30942                                  |             |                      |                   |                |                        |                      |                |                          |                  |           |

**Remark:** Test performed in general accordance with signatored referenced ASTM Method.



**Kenneth Mosman**

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

Date : 01/09/2025  
Project No : 2024C202  
Client Company : CCG  
Arrival Time : 01/09/2025 07:45  
Onsite Hours :

ASEC Report ID : 75199  
Name of the Project : Old Griffin Rd - Hawthorne Reserve  
Project Location : Dallas  
Weather : Clear sky  
Departure Time : 01/09/2025  
ASEC Technician Name : Solomon Cherie

---

**PROCTOR DATA SUMMARY**

| TEST DATE  | PROCTOR ID | MAX DRY DENSITY (pcf) | OPTIMUM MOISTURE (%) | PROCTOR TYPE | SOIL DESCRIPTION |
|------------|------------|-----------------------|----------------------|--------------|------------------|
| 10/16/2024 | S-01       | 101.9                 | 20.5                 | Standard     | Tan Clayey SILT  |
| 10/31/2024 | S-02       | 97.2                  | 24.9                 | Standard     | Red Sandy CLAY   |