

Date : 01/15/2025
Project No : 2024C202
Client Company : CCG
Arrival Time : 01/15/2025 07:30
Onsite Hours : 08:00

ASEC Report ID : 75823
Name of the Project : Old Griffin Rd - Hawthorne Reserve
Project Location : Dallas
Weather : Clear sky
Departure Time : 01/15/2025 15:30
ASEC Technician Name : Solomon Cherie

Our AS Engineering & Consulting (ASEC) representative arrived on site to observe field activities. The following tasks were performed:

Due to high in-place moisture contents (over 32%), contractor spent the day scarifying and aerating surficial soils in order to dry the site out due to recent inclement weather.

Please contact us if you have any questions regarding this report or of the density test results.



Picture showing tilled and scarified due to high moisture content

Kenneth Mosman

Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.