

Date : 01/28/2025
Project No : 2024C202
Client Company : CCG
Arrival Time : 01/28/2025 09:00
Onsite Hours : 01:30

ASEC Report ID : 76598
Name of the Project : Old Griffin Rd - Hawthorne Reserve
Project Location : Dallas
Weather : Partly cloudy
Departure Time : 01/28/2025 10:30
ASEC Technician Name : Solomon Cherie

Our AS Engineering & Consulting (ASEC) representative arrived on site to observe field activities. The following tasks were performed:

Upon arrival, our representative found the site surficial soils to be very high in moisture content (measured 34% and higher) from recent inclement weather. After consultation with the contractor, it was decided that grading operations would be terminated for the day.

Please contact us if you have any questions regarding this report.



Picture depicting muddy and shining surface due to ice layer

Kenneth Mosman

Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.