

Date : 03/20/2025
Project No : 2024C202
Client Company : CCG
Arrival Time : 03/20/2025 08:00
Onsite Hours : 03:30

ASEC Report ID : 78928
Name of the Project : Old Griffin Rd - Hawthorne Reserve
Project Location : Dallas
Weather : Partly cloudy
Departure Time : 03/20/2025 11:30
ASEC Technician Name : Solomon Cherie

Our AS Engineering & Consulting (ASEC) representative arrived on site to observe field activities. The following tasks were performed:

Upon arrival on site, our representative found the site too wet to perform grading activities. Following an attempt at fill placement and compaction, several density test results displayed high moisture contents (over 30%) with low compaction results. After a discussion, the grading contractor decided to scarify and aerate surficial soils for the rest of the day.

Please contact us if you have any questions regarding this report.



Picture depicting too wet dirt to be scarify

Kenneth Mosman

Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.