

Date : 03/27/2025
Project No : 2024C202
Client Company : CCG
Arrival Time : 03/27/2025 07:30
Onsite Hours : 02:30

ASEC Report ID : 79130
Name of the Project : Old Griffin Rd - Hawthorne Reserve
Project Location : Dallas
Weather : Sunny
Departure Time : 03/27/2025 10:00
ASEC Technician Name : Solomon Cherie

Our AS Engineering & Consulting (ASEC) representative arrived on site to observe field activities. The following tasks were performed:

Observed the placement of backfill for the sewer line between manholes B9 and B-10 today. During excavation and pipe placement, groundwater water was observed to be seeping into the excavation. It was recommended to remove any soft soils followed by the placement of No. 57 stone to begin out of the bottom of the trench.

Please contact us if you have any questions regarding this report or of the density test results.



Sewer line b/n Manholes B9 and B10

Kenneth Mosman

Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.