

Date : 04/02/2025
 Project No : 2024C202
 Client Company : CCG
 Arrival Time : 04/02/2025 07:30
 Onsite Hours :

ASEC Report ID : 79381
 Name of the Project : Old Griffin Rd - Hawthorne Reserve
 Project Location : Dallas
 Weather :
 Departure Time :
 ASEC Technician Name :

Test Date	Test Number	Moisture Content (%)	Dry Density (pcf)	Proctor Number	Max. Dry Density (pcf)	Optimum Moisture (%)	Compaction (%)	Specified Compaction (%)	ASTM Test Method	Pass/Fail
04/02/2025	1	31	88.1	ASECP006	92.1	27.0	95.7	95	D6938	Pass
Location : Lot #49, Elv/Depth :6 feet below finished grade Comment : In-situ moisture contents are much higher than optimum. Tested By : Solomon Cherie Gauge Serial No. : 30942										
04/02/2025	2	31.0	89.6	ASECP006	92.1	27.0	97.3	95	D6938	Pass
Location : Lot #48, Elv/Depth :3 feet below finished grade Comment : In-situ moisture contents are much higher than optimum. Tested By : Solomon Cherie Gauge Serial No. :										

Remark: Test performed in general accordance with signed referenced ASTM Method.



Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

Date : 04/02/2025
 Project No : 2024C202
 Client Company : CCG
 Arrival Time : 04/02/2025 07:30
 Onsite Hours :

ASEC Report ID : 79381
 Name of the Project : Old Griffin Rd - Hawthorne Reserve
 Project Location : Dallas
 Weather :
 Departure Time :
 ASEC Technician Name :

PROCTOR DATA SUMMARY

TEST DATE	PROCTOR ID	MAX DRY DENSITY (pcf)	OPTIMUM MOISTURE (%)	PROCTOR TYPE	SOIL DESCRIPTION
10/16/2024	S-01	101.9	20.5	Standard	Tan Clayey SILT
10/31/2024	S-02	97.2	24.9	Standard	Red Sandy CLAY
03/14/2025	ASECP006	92.1	27.0	Standard	Red brown Silty CLAY