

Date : 07/01/2025
Project No : 2024C202
Client Company : CCG
Arrival Time : 07/01/2025 12:00
Onsite Hours : 04:00

ASEC Report ID : 82801
Name of the Project : Old Griffin Rd - Hawthorne Reserve
Project Location : Dallas
Weather : sunny
Departure Time : 07/01/2025 16:00
ASEC Technician Name : Aminullah Azimi


As requested, a representative from AS Engineering and Consulting (ASEC) visited the site to perform quality control inspection and testing services. Visual observation techniques were employed to verify compliance with project drawings/specifications, applicable codes, and approved material submittals. The following observations were made during the site visit:

Performed a proof-roll and conducted DCP (Dynamic Cone Penetrometer) testing on this day.

A proof-roll was performed on the road (location is shown in pictures) using a fully loaded tandem-axle dump truck. Multiple passes were made across the area. No significant yielding or deflection was observed during the proof-roll.

The proof-roll was observed by our representative, David Howell with Baldwin paving rep, Mike Keemer with Paulding DOT and George from CCG.

We appreciate the opportunity to support your project. If you have any questions regarding this report, please do not hesitate to contact us. We are happy to discuss our findings in greater detail.



Date : 07/01/2025
Project No : 2024C202
Client Company : CCG
Arrival Time : 07/01/2025 12:00
Onsite Hours : 04:00

ASEC Report ID : 82801
Name of the Project : Old Griffin Rd - Hawthorne Reserve
Project Location : Dallas
Weather : sunny
Departure Time : 07/01/2025 16:00
ASEC Technician Name : Aminullah Azimi



Kenneth Mosman

Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.