

Date : 03/20/2025
 Project No : 2024C213
 Client Company : WDG
 Arrival Time : 03/20/2025 10:00
 Onsite Hours : 06:30

ASEC Report ID : 79010
 Name of the Project : Covington Town Center PH II
 Project Location : Covington, GA
 Weather : Clear
 Departure Time : 03/20/2025 16:30
 ASEC Technician Name : Clyde Smith

Test Date	Test Number	Moisture Content (%)	Dry Density (pcf)	Proctor Number	Max. Dry Density (pcf)	Optimum Moisture (%)	Compaction (%)	Specified Compaction (%)	ASTM Test Method	Pass/Fail
03/20/2025	1	20.6	101.2	ASECP001	106.0	18.2	95.5	95	D6938	Pass
Location : Bldg. pad 18' west of SE corner, Elv/Depth :817.00										
Comment :										
Tested By : Clyde Smith Gauge Serial No. : 29588										
03/20/2025	2	21.3	102.3	ASECP001	106.0	18.2	96.5	95	D6938	Pass
Location : Bldg pad 30' west, 40' N of SE corner, Elv/Depth :817.00										
Comment :										
Tested By : Clyde Smith Gauge Serial No. : 29588										
03/20/2025	3	19.9	103.8	ASECP001	106.0	18.2	97.9	95	D6938	Pass
Location : Bldg.pad 70' west, 40'N of SE corner, Elv/Depth :818.5										
Comment :										
Tested By : Clyde Smith Gauge Serial No. : 29588										
03/20/2025	4	18.2	102.3	ASECP001	106.0	18.2	96.5	95	D6938	Pass
Location : Bldg.pad 20'west, 25'N of SE.corner, Elv/Depth :819.5										
Comment :										
Tested By : Clyde Smith Gauge Serial No. : 29588										
03/20/2025	5	18.3	103.0	ASECP001	106.0	18.2	97.2	95	D6938	Pass
Location : Bldg.pad 70'N, 35'west of SE. corner, Elv/Depth :819.00										
Comment :										
Tested By : Clyde Smith Gauge Serial No. : 29855										
03/20/2025	6	20.2	104.1	ASECP001	106.0	18.2	98.2	95	D6938	Pass
Location : Bldg.pad 78'N, 46'west of SE.corner, Elv/Depth :820.00										
Comment :										
Tested By : Clyde Smith Gauge Serial No. : 29855										
03/20/2025	7	20.9	104.7	ASECP001	106.0	18.2	98.8	95	D6938	Pass
Location : Bldg.pad 65' west, 60'N of SE.corner, Elv/Depth :820.5										
Comment :										
Tested By : Clyde Smith Gauge Serial No. : 29855										

Remark: Test performed in general accordance with signed referenced ASTM Method.



Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

Date : 03/20/2025
Project No : 2024C213
Client Company : WDG
Arrival Time : 03/20/2025 10:00
Onsite Hours : 06:30

ASEC Report ID : 79010
Name of the Project : Covington Town Center PH II
Project Location : Covington, GA
Weather : Clear
Departure Time : 03/20/2025 16:30
ASEC Technician Name : Clyde Smith

PROCTOR DATA SUMMARY

TEST DATE	PROCTOR ID	MAX DRY DENSITY (pcf)	OPTIMUM MOISTURE (%)	PROCTOR TYPE	SOIL DESCRIPTION
03/06/2025	ASECP001	106.0	18.2	Standard	Red Clayey SAND with silt
04/17/2025	2025-017 SP	99.0	18.3	Standard	Brown Silty SAND