

Date : 03/25/2025  
 Project No : 2024C213  
 Client Company : WDG  
 Arrival Time : 03/25/2025 14:00  
 Onsite Hours : 02:30

ASEC Report ID : 79114  
 Name of the Project : Covington Town Center PH II  
 Project Location : Covington, GA  
 Weather :  
 Departure Time : 03/25/2025 16:30  
 ASEC Technician Name : Clyde Smith

Test Date	Test Number	Moisture Content (%)	Dry Density (pcf)	Proctor Number	Max. Dry Density (pcf)	Optimum Moisture (%)	Compaction (%)	Specified Compaction (%)	ASTM Test Method	Pass/Fail
03/25/2025	1	16.8	105.1	ASECP001	106.0	18.2	99.2	98	D6938	Pass
Location : NE building. corner, Elv/Depth :822.00										
Comment :										
Tested By : Clyde Smith Gauge Serial No. : 29855										
03/25/2025	2	17.0	106.1	ASECP001	106.0	18.2	100.1	98	D6938	Pass
Location : SE corner of building, Elv/Depth :822.00										
Comment :										
Tested By : Clyde Smith Gauge Serial No. : 29588										
03/25/2025	3	16.5	104.3	ASECP001	106.0	18.2	98.4	98	D6938	Pass
Location : SW corner of building, Elv/Depth :822.0										
Comment :										
Tested By : Clyde Smith Gauge Serial No. : 29588										
03/25/2025	4	17.4	104.3	ASECP001	106.0	18.2	98.4	98	D6938	Pass
Location : NW corner of building, Elv/Depth :822.0										
Comment :										
Tested By : Clyde Smith Gauge Serial No. : 29588										

**Remark:** Test performed in general accordance with signed referenced ASTM Method.



**Kenneth Mosman**

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

Date : 03/25/2025  
Project No : 2024C213  
Client Company : WDG  
Arrival Time : 03/25/2025 14:00  
Onsite Hours : 02:30

ASEC Report ID : 79114  
Name of the Project : Covington Town Center PH II  
Project Location : Covington, GA  
Weather :  
Departure Time : 03/25/2025 16:30  
ASEC Technician Name : Clyde Smith

---

**PROCTOR DATA SUMMARY**

TEST DATE	PROCTOR ID	MAX DRY DENSITY (pcf)	OPTIMUM MOISTURE (%)	PROCTOR TYPE	SOIL DESCRIPTION
03/06/2025	ASECP001	106.0	18.2	Standard	Red Clayey SAND with silt
04/17/2025	2025-017 SP	99.0	18.3	Standard	Brown Silty SAND