

Date : 04/10/2025  
 Project No : 2024C213  
 Client Company : WDG  
 Arrival Time : 04/10/2025 9:00  
 Onsite Hours : 9:00

ASEC Report ID : 80269  
 Name of the Project : Covington Town Center PH II  
 Project Location : Covington, GA  
 Weather : sunny  
 Departure Time : 04/10/2025 18:00  
 ASEC Technician Name : Aminullah Azimi

Test Date	Test Number	Moisture Content (%)	Dry Density (pcf)	Proctor Number	Max. Dry Density (pcf)	Optimum Moisture (%)	Compaction (%)	Specified Compaction (%)	ASTM Test Method	Pass/Fail
04/10/2025	1	18.5	103.6	ASECP001	106.0	18.2	97.7	95	D6938	Pass
Location : water storm trench, between MHB1 and MHB2, Elv/Depth :3 feet below finished grade										
Comment :										
Tested By : Aminullah Azimi Gauge Serial No. : 85759										
04/10/2025	2	19.2	104.4	ASECP001	106.0	18.2	98.5	95	D6938	Pass
Location : water storm trench, 22 feet west from MHB2, Elv/Depth :2 feet below finished grade										
Comment :										
Tested By : Aminullah Azimi Gauge Serial No. : 85759										
04/10/2025	3	20	105.6	ASECP001	106.0	18.2	99.6	95	D6938	Pass
Location : sewer trench, 31 feet west from existing MH , Elv/Depth :7 feet below finished grade										
Comment :										
Tested By : Aminullah Azimi Gauge Serial No. : 85759										

**Remark:** Test performed in general accordance with signed referenced ASTM Method.



**Kenneth Mosman**

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

Date : 04/10/2025  
Project No : 2024C213  
Client Company : WDG  
Arrival Time : 04/10/2025 9:00  
Onsite Hours : 9:00

ASEC Report ID : 80269  
Name of the Project : Covington Town Center PH II  
Project Location : Covington, GA  
Weather : sunny  
Departure Time : 04/10/2025 18:00  
ASEC Technician Name : Aminullah Azimi

**PROCTOR DATA SUMMARY**

TEST DATE	PROCTOR ID	MAX DRY DENSITY (pcf)	OPTIMUM MOISTURE (%)	PROCTOR TYPE	SOIL DESCRIPTION
03/06/2025	ASECP001	106.0	18.2	Standard	Red Clayey SAND with silt
04/17/2025	2025-017 SP	99.0	18.3	Standard	Brown Silty SAND
04/15/2025	28586	98.7	20.6	Standard	Gray Brown Sandy Silt