

Date : 04/17/2025
Project No : 2024C213
Client Company : WDG
Arrival Time : 04/17/2025 8:00
Onsite Hours : 9:30

ASEC Report ID : 81159
Name of the Project : Covington Town Center PH II
Project Location : Covington, GA
Weather : sunny
Departure Time : 04/17/2025 17:30
ASEC Technician Name : Aminullah Azimi

Test Date	Test Number	Moisture Content (%)	Dry Density (pcf)	Proctor Number	Max. Dry Density (pcf)	Optimum Moisture (%)	Compaction (%)	Specified Compaction (%)	ASTM Test Method	Pass/Fail
04/17/2025	1	17.7	103.7	ASECP001	106.0	18.2	97.8	95	D6938	Pass
Location : storm trench, between MHA0 and MHB1, Elv/Depth :2 feet below finished grade										
Comment :										
Tested By : Aminullah Azimi Gauge Serial No. : 85759										
04/17/2025	2	16.2	95.3	2025-017 SP	99.0	18.3	96.3	95	D6938	Pass
Location : service line, in front of building, Elv/Depth :3 feet below finished grade										
Comment :										
Tested By : Aminullah Azimi Gauge Serial No. : 85759										
04/17/2025	3	16.7	103.6	ASECP001	106.0	18.2	97.7	95	D6938	Pass
Location : sewer trench, 25 feet to the east from existing MH, Elv/Depth :1.5 feet below finished grade										
Comment :										
Tested By : Aminullah Azimi Gauge Serial No. : 85759										
04/17/2025	4	19.2	95.6	2025-017 SP	99.0	18.3	96.6	95	D6938	Pass
Location : water storm trench, between MHB1 and MH B2, Elv/Depth :2.5 feet below finished grade										
Comment :										
Tested By : Aminullah Azimi Gauge Serial No. : 85759										
04/17/2025	5	16.5	103.9	ASECP001	106.0	18.2	98.0	95	D6938	Pass
Location : water storm trench, between MHB2 and MHB3, Elv/Depth :1.5 feet below finished grade										
Comment :										
Tested By : Aminullah Azimi Gauge Serial No. : 85759										
04/17/2025	6	16.9	104.4	ASECP001	106.0	18.2	98.5	95	D6938	Pass
Location : water storm trench, between MHB3 and MHB4, Elv/Depth :1 foot below finished grade										
Comment :										
Tested By : Aminullah Azimi Gauge Serial No. : 85759										
04/17/2025	7	17.6	103.8	ASECP001	106.0	18.2	97.9	95	D6938	Pass
Location : water storm trench, 78 feet below to the west from MHD1, Elv/Depth :1.5 feet below finished grade										
Comment :										
Tested By : Aminullah Azimi Gauge Serial No. : 85759										
04/17/2025	8	20.1	94.4	28586	98.7	20.6	95.6	95	D6938	Pass
Location : water storm trench, 16 feet to the SW from MHB1, Elv/Depth :1.5 feet below finished grade										
Comment :										
Tested By : Aminullah Azimi Gauge Serial No. : 85759										
04/17/2025	9	17.1	105.0	ASECP001	106.0	18.2	99.1	95	D6938	Pass
Location : water storm trench, between MHA0 and MHB1, Elv/Depth :at finished grade										
Comment :										
Tested By : Aminullah Azimi Gauge Serial No. : 85759										
04/17/2025	10	17.2	120.1	ASECP001	106.0	18.2	96.7	95	D6938	Pass
Location : service line, in the front of building , Elv/Depth :2 feet below finished grade										
Comment :										
Tested By : Aminullah Azimi Gauge Serial No. : 85759										

Date : 04/17/2025
Project No : 2024C213
Client Company : WDG
Arrival Time : 04/17/2025 8:00
Onsite Hours : 9:30

ASEC Report ID : 81159
Name of the Project : Covington Town Center PH II
Project Location : Covington, GA
Weather : sunny
Departure Time : 04/17/2025 17:30
ASEC Technician Name : Aminullah Azimi

Remark: Test performed in general accordance with signed referenced ASTM Method.

Kenneth Mosman

Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

Date : 04/17/2025
 Project No : 2024C213
 Client Company : WDG
 Arrival Time : 04/17/2025 8:00
 Onsite Hours : 9:30

ASEC Report ID : 81159
 Name of the Project : Covington Town Center PH II
 Project Location : Covington, GA
 Weather : sunny
 Departure Time : 04/17/2025 17:30
 ASEC Technician Name : Aminullah Azimi

PROCTOR DATA SUMMARY

TEST DATE	PROCTOR ID	MAX DRY DENSITY (pcf)	OPTIMUM MOISTURE (%)	PROCTOR TYPE	SOIL DESCRIPTION
03/06/2025	ASECP001	106.0	18.2	Standard	Red Clayey SAND with silt
04/17/2025	2025-017 SP	99.0	18.3	Standard	Brown Silty SAND
04/15/2025	28586	98.7	20.6	Standard	Gray Brown Sandy Silt