

Date : 04/30/2025  
Project No : 2024C213  
Client Company : WDG  
Arrival Time : 04/30/2025 7:00  
Onsite Hours : 05:00

ASEC Report ID : 81702  
Name of the Project : Covington Town Center PH II  
Project Location : Covington, GA  
Weather : sunny  
Departure Time : 04/30/2025 12:00  
ASEC Technician Name : Aminullah Azimi

---

**Location(S):** building pad, building pad

**Testing:** 2 Set of concrete specimens (5 Cylinders per set) were cast during the cast-in-place concrete pour at the above referenced location, in accordance with ASTM C31. The cylinders will remain on site for the initial 24-48 hrs curing.

**Compliance:** ☒ Field placement of concrete appeared to be in general accordance with the project specifications (i.e., slump, temperature, etc) (refer to remarks below)  
☐ Deviations and/or noncompliances were noted during the field placement (refer to remarks below)

**Cylinders Pick Up:** 2 Sets of concrete cylinders/ 5 cylinders per set were picked up & transported to AS Engineering and Consulting LLC (ASEC) for curing and testing in accordance with ASTM C39, C670/1231

**Field Curing:** Cylinders were stored for the initial 24 hours  
☒ Near the poured structure  
☐ In an insulated curing box  
☐ Other

**Remarks:**

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

Date : 04/30/2025  
Project No : 2024C213  
Client Company : WDG  
Arrival Time : 04/30/2025 7:00  
Onsite Hours : 05:00

ASEC Report ID : 81702  
Name of the Project : Covington Town Center PH II  
Project Location : Covington, GA  
Weather : sunny  
Departure Time : 04/30/2025 12:00  
ASEC Technician Name : Aminullah Azimi

**PLACEMENT INFORMATION**

<b>Set Number:</b> A	<b>Laboratory Number:</b> A
<b>Date Sampled:</b> 04/30/2025	<b>Time Sampled:</b> 8:00
<b>Sampled By:</b> Aminullah Azimi	<b>Concrete Supplier:</b> Thomas
<b>Contractor:</b>	<b>Mix ID:</b> 302-3Fs
<b>Truck Number:</b> 2096	<b>Quantity of Load (cu. yd.):</b> 9
<b>Time Batched:</b> 7:58	<b>Specified Strength :</b> 3000
<b>Location of Placement:</b> building pad	<b>Concrete Temperature(°f):</b> 74
<b>Number of samples cast:</b> 5	<b>Air Content (%) :</b> 1.5
<b>Ambient Temperature (°f):</b> 73	<b>Water added (gal.):</b>
<b>Slump (in.):</b> 5	

Specimen Number	Age (Days)	Date Tested	Dia(in.)	Area (sq in.)	Maximum Loads (lbs)	Strength (psi)	% Design Strength	Type of Fracture
1	7	05/07/2025						
2	28	05/28/2025						
3	28	05/28/2025						
4	58	06/27/2025						
5	58	06/27/2025						

UNLESS OTHERWISE SPECIFIED, TESTS WERE PERFORMED IN ACCORDANCE WITH ASTM TEST METHODS C31, C39, C138, C143, C173, AND C1064. FRACTURE TYPE INDICATED BY NUMBER

(Type 1) Cone (Type 2) Cone-split (Type 3) Vertical (Type 4) Shear (Type 5) Edge Fracture (Type 6) Pointed

  
Kenneth Mosman

Date : 04/30/2025  
Project No : 2024C213  
Client Company : WDG  
Arrival Time : 04/30/2025 7:00  
Onsite Hours : 05:00

ASEC Report ID : 81702  
Name of the Project : Covington Town Center PH II  
Project Location : Covington, GA  
Weather : sunny  
Departure Time : 04/30/2025 12:00  
ASEC Technician Name : Aminullah Azimi

**PLACEMENT INFORMATION**

<b>Set Number:</b> B	<b>Laboratory Number:</b> B
<b>Date Sampled:</b> 04/30/2025	<b>Time Sampled:</b> 11:06
<b>Sampled By:</b> Aminullah Azimi	<b>Concrete Supplier:</b> Thomas
<b>Contractor:</b>	<b>Mix ID:</b> 302-3Fs
<b>Truck Number:</b> 2096	<b>Quantity of Load (cu. yd.):</b> 9
<b>Time Batched:</b> 9:56	<b>Specified Strength :</b> 3000
<b>Location of Placement:</b> building pad	<b>Concrete Temperature(°f):</b> 74
<b>Number of samples cast:</b> 5	<b>Air Content (%) :</b> 1.5
<b>Ambient Temperature (°f):</b> 73	<b>Water added (gal.):</b> 0
<b>Slump (in.):</b> 5	

Specimen Number	Age (Days)	Date Tested	Dia(in.)	Area (sq in.)	Maximum Loads (lbs)	Strength (psi)	% Design Strength	Type of Fracture
1	7	05/07/2025	8					
2	28	05/28/2025	8					
3	28	05/28/2025	8					
4	28	05/28/2025	8					
4	58	06/27/2025	8					
5	58	06/27/2025	8					

UNLESS OTHERWISE SPECIFIED, TESTS WERE PERFORMED IN ACCORDANCE WITH ASTM TEST METHODS C31, C39, C138, C143, C173, AND C1064. FRACTURE TYPE INDICATED BY NUMBER

(Type 1) Cone (Type 2) Cone-split (Type 3) Vertical (Type 4) Shear (Type 5) Edge Fracture (Type 6) Pointed

*Kenneth Mosman*

Kenneth Mosman