

Date : 07/09/2025
Project No : 2024C213
Client Company : WDG
Arrival Time : 07/09/2025 08:30
Onsite Hours : 03:00

ASEC Report ID : 82884
Name of the Project : Covington Town Center PH II
Project Location : Covington, GA
Weather : sunny
Departure Time : 07/09/2025 11:30
ASEC Technician Name : Sean Willett

As requested, the site was visited by our AS Engineering and Consulting (ASEC) representative for the purpose of providing quality control inspection and testing services. Visual observation techniques were employed to verify compliance with project drawing/specifications, applicable codes, and materials submittals. The following observations were observed on site this day.

On the above date, the technician was on site as requested by the contractor (Fulcrum) to perform a proof-roll of the entire site.

The technician and contractor observed a proof-roll using a loaded tandem axled dump truck. The technician was accompanied by Buck Vinson, the site superintendent. There were no signs of severe pumping/rutting or instability. The proof-roll was performed over top of the previously backfilled electrical and gas lines as well. There were no signs of poor stability. The technician also generally probed random areas using a 3/8" diameter probe rod during proof-rolling, especially in visibly wet areas. These areas did not show any signs of poor stability.

We appreciate the opportunity to be of service to you on this project. If you have any questions regarding this report, please feel free to contact us. We will be more than happy to discuss it with you.



Kenneth Mosman

Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.