

Date : 07/23/2025  
Project No : 2024C213  
Client Company : WDG  
Arrival Time : 07/23/2025 08:45  
Onsite Hours : 06:45


ASEC Report ID : 83590  
Name of the Project : Covington Town Center PH II  
Project Location : Covington, GA  
Weather : Light rain  
Departure Time : 07/23/2025 15:30  
ASEC Technician Name : Austin Coleman

As requested, the site was visited by our AS Engineering and Consulting (ASEC) representative for the purpose of providing quality control inspection and testing services. Visual observation techniques were employed to verify compliance with project drawing/specifications, applicable codes, and materials submittals. The following observations were observed on site this day.

Our ASEC representative arrived on site to observe a proof-roll on the subgrade of the parking lot and to perform general probing using a 3/8" diameter probe rod. Four areas were identified as needing remedial work done due soft soils and/or standing water which contributed to some pumping/rutting of surficial soils.

In addition, pervious concrete was placed for four parking spaces and two temperature readings were taken (one per truckload). The readings were 92- and 97-degrees Fahrenheit.

We appreciate the opportunity to be of service to you on this project. If you have any questions regarding this report, please feel free to contact us. We will be more than happy to discuss it with you.



Date : 07/23/2025  
Project No : 2024C213  
Client Company : WDG  
Arrival Time : 07/23/2025 08:45  
Onsite Hours : 06:45

ASEC Report ID : 83590  
Name of the Project : Covington Town Center PH II  
Project Location : Covington, GA  
Weather : Light rain  
Departure Time : 07/23/2025 15:30  
ASEC Technician Name : Austin Coleman



*Kenneth Mosman*

**Kenneth Mosman**

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.