

Date : 03/26/2025  
 Project No : 2024C217  
 Client Company : Artisan  
 Arrival Time : 03/26/2025 12:30  
 Onsite Hours :

ASEC Report ID : 79099  
 Name of the Project : Naturewalk - 7 Hills Amenities  
 Project Location : Dallas  
 Weather : Sunny  
 Departure Time : 03/26/2025  
 ASEC Technician Name : Solomon Cherie

Test Date	Test Number	Moisture Content (%)	Dry Density (pcf)	Proctor Number	Max. Dry Density (pcf)	Optimum Moisture (%)	Compaction (%)	Specified Compaction (%)	ASTM Test Method	Pass/Fail
03/26/2025	1	12.9	106.4	P-01	107.7	16.4	98.8	95	D6938	Pass
Location : Pickle ball field, Elv/Depth :at finished subgrade										
Comment :										
Tested By : Solomon Cherie Gauge Serial No. : 30942										

**Remark:** Test performed in general accordance with signed referenced ASTM Method.



**Kenneth Mosman**

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

Date : 03/26/2025  
Project No : 2024C217  
Client Company : Artisan  
Arrival Time : 03/26/2025 12:30  
Onsite Hours :

ASEC Report ID : 79099  
Name of the Project : Naturewalk - 7 Hills Amenities  
Project Location : Dallas  
Weather : Sunny  
Departure Time : 03/26/2025  
ASEC Technician Name : Solomon Cherie

---

**PROCTOR DATA SUMMARY**

TEST DATE	PROCTOR ID	MAX DRY DENSITY (pcf)	OPTIMUM MOISTURE (%)	PROCTOR TYPE	SOIL DESCRIPTION
10/31/2024	P-01	107.7	16.4	Standard	Yellow-brown Sandy SILT