

Date : 03/27/2025
 Project No : 2024C217
 Client Company : Artisan
 Arrival Time : 03/27/2025 :
 Onsite Hours :

ASEC Report ID : 79124
 Name of the Project : Naturewalk - 7 Hills Amenities
 Project Location : Dallas
 Weather : Clear sky
 Departure Time :
 ASEC Technician Name : Solomon Cherie

Test Date	Test Number	Moisture Content (%)	Dry Density (pcf)	Proctor Number	Max. Dry Density (pcf)	Optimum Moisture (%)	Compaction (%)	Specified Compaction (%)	ASTM Test Method	Pass/Fail
03/27/2025	1	13.5	111.6	P-01	107.7	16.4	103.6	95	D6938	Pass
Location : Pickle ball court, Elv/Depth :6 inches below finished grade										
Comment : A new proctor sample was obtained and returned to our laboratory for a new proctor test.										
Tested By : Solomon Cherie Gauge Serial No. : 30942										

Remark: Test performed in general accordance with signaturred referenced ASTM Method.



Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

Date : 03/27/2025
Project No : 2024C217
Client Company : Artisan
Arrival Time : 03/27/2025 :
Onsite Hours :

ASEC Report ID : 79124
Name of the Project : Naturewalk - 7 Hills Amenities
Project Location : Dallas
Weather : Clear sky
Departure Time :
ASEC Technician Name : Solomon Cherie

PROCTOR DATA SUMMARY

TEST DATE	PROCTOR ID	MAX DRY DENSITY (pcf)	OPTIMUM MOISTURE (%)	PROCTOR TYPE	SOIL DESCRIPTION
10/31/2024	P-01	107.7	16.4	Standard	Yellow-brown Sandy SILT