

Date : 06/21/2025
Project No : 2024C217
Client Company : Artisan
Arrival Time : 06/21/2025 8:00
Onsite Hours : 07:00

ASEC Report ID : 82777
Name of the Project : Naturewalk - 7 Hills Amenities
Project Location : Dallas
Weather : sunny
Departure Time : 06/21/2025 15:00
ASEC Technician Name : Aminullah Azimi

Test Date	Test Number	Moisture Content (%)	Dry Density (pcf)	Proctor Number	Max. Dry Density (pcf)	Optimum Moisture (%)	Compaction (%)	Specified Compaction (%)	ASTM Test Method	Pass/Fail
06/21/2025	1	20	103.3	26881	107.7	16.4	95.9	95	D6938	Pass
Location : Water trench (location shown in picture), Elv/Depth :2.5 feet below finished grade										
Comment :										
Tested By : Aminullah Azimi Gauge Serial No. : 85759										
06/21/2025	2	20.1	105.0	26881	107.7	16.4	97.5	95	D6938	Pass
Location : Water trench (location is shown in picture), Elv/Depth :3 feet below finished grade										
Comment :										
Tested By : Aminullah Azimi Gauge Serial No. : 85759										
06/21/2025	3	19.8	124.2	26881	107.7	16.4	96.3	95	D6938	Pass
Location : Water trench (location is shown in picture), Elv/Depth :1.5 feet below finished grade										
Comment :										
Tested By : Aminullah Azimi Gauge Serial No. : 85759										
06/21/2025	4	20.1	102.6	26881	107.7	16.4	95.3	95	D6938	Pass
Location : Water trench (location is shown in pictures), Elv/Depth :2 feet below finished grade										
Comment :										
Tested By : Aminullah Azimi Gauge Serial No. : 85759										

Remark: Test performed in general accordance with signed referenced ASTM Method.


Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

Date : 06/21/2025
Project No : 2024C217
Client Company : Artisan
Arrival Time : 06/21/2025 8:00
Onsite Hours : 07:00

ASEC Report ID : 82777
Name of the Project : Naturewalk - 7 Hills Amenities
Project Location : Dallas
Weather : sunny
Departure Time : 06/21/2025 15:00
ASEC Technician Name : Aminullah Azimi

PROCTOR DATA SUMMARY

TEST DATE	PROCTOR ID	MAX DRY DENSITY (pcf)	OPTIMUM MOISTURE (%)	PROCTOR TYPE	SOIL DESCRIPTION
10/31/2024	26881	107.7	16.4	Standard	Yellow-brown Sandy SILT
03/11/2025	26398	120.5	11.5	Standard	Brown Silty SAND with rock fragments
03/11/2025	26443	101.3	19.4	Standard	Reddish brown Sandy elastic SILT
03/14/2025	27681	92.5	27.7	Standard	Brown Sandy SILT
07/10/2025	2025-029MP	129.6	8.5	Standard	GAB