

Date : 07/23/2025
Project No : 2024C217
Client Company : Artisan
Arrival Time : 07/23/2025 09:00
Onsite Hours : 05:30

ASEC Report ID : 83339
Name of the Project : Naturewalk - 7 Hills Amenities
Project Location : Dallas
Weather : Mostly Cloudy
Departure Time : 07/23/2025 14:30
ASEC Technician Name : Safiullah Momand

As requested, the site was visited by our AS Engineering and Consulting (ASEC) representative for the purpose of providing quality control inspection and testing services. Visual observation techniques were employed to verify compliance with project drawing/specifications, applicable codes, and materials submittals. The following observations were observed on site this day.

Our ASEC representative observed the ongoing activities on Shealy Well Road and the deceleration lane west curbing. During the observation, it was noted that 3 to 4 inches of loose GAB material had been placed for leveling purposes. Since the GAB was laid without compaction, the technician recommended compacting it using a hand compactor to prevent potential damage to the side curb work in the future.

We appreciate the opportunity to be of service to you on this project. If you have any questions regarding this report, please feel free to contact us. We will be more than happy to discuss it with you.




Deceleration lane side curb shuttering work



Deceleration lane side curb shuttering work

Date : 07/23/2025
Project No : 2024C217
Client Company : Artisan
Arrival Time : 07/23/2025 09:00
Onsite Hours : 05:30

ASEC Report ID : 83339
Name of the Project : Naturewalk - 7 Hills Amenities
Project Location : Dallas
Weather : Mostly Cloudy
Departure Time : 07/23/2025 14:30
ASEC Technician Name : Safiullah Momand



Deceleration lane side curb shuttering work



Deceleration lane side curb shuttering work



Deceleration lane side curb shuttering work



GAB work in Shealy road.

Kenneth Mosman

Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.