

Date : 01/30/2025  
 Project No : 2024C237  
 Client Company : SR Homes  
 Arrival Time : 01/30/2025 9:30  
 Onsite Hours : 08:30

ASEC Report ID : 78014  
 Name of the Project : Stonewood PH 4, Stone Road  
 Project Location : Watkinsville  
 Weather : sunny  
 Departure Time : 01/30/2025 18:00  
 ASEC Technician Name : Aminullah Azimi

Test Date	Test Number	Moisture Content (%)	Dry Density (pcf)	Proctor Number	Max. Dry Density (pcf)	Optimum Moisture (%)	Compaction (%)	Specified Compaction (%)	ASTM Test Method	Pass/Fail
01/30/2025	1	23.4	99.0	S-02	104.0	19.1	95.2	95	D6938	Pass
Location : Water line in front of Lot #87, Elv/Depth :2 feet below finished grade										
Comment :										
Tested By : Aminullah Azimi Gauge Serial No. : 85759										
01/30/2025	2	22.1	101.2	S-02	104.0	19.1	97.3	95	D6938	Pass
Location : Water line in front of Lot #88, Elv/Depth :2 feet below finished grade										
Comment :										
Tested By : Aminullah Azimi Gauge Serial No. : 85759										
01/30/2025	3	22.3	99.8	S-02	104.0	19.1	96.0	95	D6938	Pass
Location : Water line in front of Lot #87, Elv/Depth :1.5 foot below finished grade										
Comment :										
Tested By : Aminullah Azimi Gauge Serial No. : 85759										
01/30/2025	4	21.7	99.3	S-02	104.0	19.1	95.5	95	D6938	Pass
Location : Water line in front of Lot #87, Elv/Depth :0.5 foot below finished grade										
Comment :										
Tested By : Aminullah Azimi Gauge Serial No. : 85759										
01/30/2025	5	23.9	99.3	S-02	104.0	19.1	95.5	95	D6938	Pass
Location : Water line in front of Lot #88, Elv/Depth :0.5 foot below finished grade										
Comment :										
Tested By : Aminullah Azimi Gauge Serial No. : 85759										
01/30/2025	6	22.2	100.7	S-02	104.0	19.1	96.8	95	D6938	Pass
Location : Water line in front of roundabout , Elv/Depth :1.5 feet below finished grade										
Comment :										
Tested By : Aminullah Azimi Gauge Serial No. : 85759										
01/30/2025	7	22.1	100.3	S-02	104.0	19.1	96.4	95	D6938	Pass
Location : Water line in front of Lot #87, Elv/Depth :at finished grade										
Comment :										
Tested By : Aminullah Azimi Gauge Serial No. : 85759										
01/30/2025	8	20.6	100.5	S-02	104.0	19.1	96.6	95	D6938	Pass
Location : Water line at roundabout in front of Lot #88, Elv/Depth :at finished grade										
Comment :										
Tested By : Aminullah Azimi Gauge Serial No. : 85759										

**Remark:** Test performed in general accordance with signed referenced ASTM Method.



**Kenneth Mosman**

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

Date : 01/30/2025  
Project No : 2024C237  
Client Company : SR Homes  
Arrival Time : 01/30/2025 9:30  
Onsite Hours : 08:30

ASEC Report ID : 78014  
Name of the Project : Stonewood PH 4, Stone Road  
Project Location : Watkinsville  
Weather : sunny  
Departure Time : 01/30/2025 18:00  
ASEC Technician Name : Aminullah Azimi

---

**PROCTOR DATA SUMMARY**

TEST DATE	PROCTOR ID	MAX DRY DENSITY (pcf)	OPTIMUM MOISTURE (%)	PROCTOR TYPE	SOIL DESCRIPTION
10/07/2024	S-01	101.2	18.6	Standard	Light Brown Sandy SILT
10/07/2024	S-02	104.0	19.1	Standard	Reddish Brown Silty CLAY