

Date : 02/27/2025
Project No : 2024C237
Client Company : SR Homes
Arrival Time : 02/27/2025 12:00
Onsite Hours : 04:30

ASEC Report ID : 79178
Name of the Project : Stonewood PH 4, Stone Road
Project Location : Watkinsville
Weather : sunny
Departure Time : 02/27/2025 16:30
ASEC Technician Name : Aminullah Azimi

Test Date	Test Number	Moisture Content (%)	Dry Density (pcf)	Proctor Number	Max. Dry Density (pcf)	Optimum Moisture (%)	Compaction (%)	Specified Compaction (%)	ASTM Test Method	Pass/Fail
02/27/2025	1	24.2	122.9	S-02	104.0	19.1	95.2	95	D6938	Pass
Location : removed outlet area at pond, Elv/Depth :4 feet below finished grade										
Comment :										
Tested By : Aminullah Azimi Gauge Serial No. : 85759										
02/27/2025	2	22.1	99.5	S-02	104.0	19.1	95.7	95	D6938	Pass
Location : removed outlet area at pond, Elv/Depth :2.5 feet below finished grade										
Comment :										
Tested By : Aminullah Azimi Gauge Serial No. : 85759										
02/27/2025	3	20.6	99.8	S-02	104.0	19.1	96.0	95	D6938	Pass
Location : removed outlet at pond , Elv/Depth :1.5 feet below finished grade										
Comment :										
Tested By : Aminullah Azimi Gauge Serial No. : 85759										
02/27/2025	4	22.3	120.9	S-02	104.0	19.1	95.1	95	D6938	Pass
Location : removed outlet area at pond , Elv/Depth :1 foot below finished grade										
Comment :										
Tested By : Aminullah Azimi Gauge Serial No. : 85759										

Remark: Test performed in general accordance with signed referenced ASTM Method.


Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

Date : 02/27/2025
Project No : 2024C237
Client Company : SR Homes
Arrival Time : 02/27/2025 12:00
Onsite Hours : 04:30

ASEC Report ID : 79178
Name of the Project : Stonewood PH 4, Stone Road
Project Location : Watkinsville
Weather : sunny
Departure Time : 02/27/2025 16:30
ASEC Technician Name : Aminullah Azimi

PROCTOR DATA SUMMARY

TEST DATE	PROCTOR ID	MAX DRY DENSITY (pcf)	OPTIMUM MOISTURE (%)	PROCTOR TYPE	SOIL DESCRIPTION
10/07/2024	S-01	101.2	18.6	Standard	Light Brown Sandy SILT
10/07/2024	S-02	104.0	19.1	Standard	Reddish Brown Silty CLAY