

Date : 03/28/2026
 Project No : 2024C296
 Client Company : Artisan
 Arrival Time : 03/28/2026 08:00
 Onsite Hours : 01:00

ASEC Report ID : 91898
 Name of the Project : Heritage Pointe - Footing Inspections
 Project Location : Villa Rica
 Weather : Sunny
 Departure Time : 03/28/2026 09:00
 ASEC Technician Name : Sean Willett

Test Date	Test Number	Moisture Content (%)	Dry Density (pcf)	Proctor Number	Max. Dry Density (pcf)	Optimum Moisture (%)	Compaction (%)	Specified Compaction (%)	ASTM Test Method	Pass/Fail
03/28/2026	1	23.4	94.1	2026-077	95.8	20.0	98.2	95	D6938	Pass
Location : Lot #109, Elv/Depth :2 feet below finished grade										
Comment :										
Tested By : Sean Willett Gauge Serial No. : 77-19952										
03/28/2026	2	22.4	95.5	2026-077	95.8	20.0	99.7	95	D6938	Pass
Location : Lot #109, Elv/Depth :2 feet below finished grade										
Comment :										
Tested By : Sean Willett Gauge Serial No. : 77-19952										
03/28/2026	3	21.6	91.1	2026-077	95.8	20.0	95.1	95	D6938	Pass
Location : Lot #109, Elv/Depth :at finished grade										
Comment :										
Tested By : Sean Willett Gauge Serial No. : 77-19952										
03/28/2026	4	21.2	91.3	2026-077	95.8	20.0	95.3	95	D6938	Pass
Location : Lot #109, Elv/Depth :at finished grade										
Comment :										
Tested By : Sean Willett Gauge Serial No. : 77-19952										

Remark: Test performed in general accordance with signed referenced ASTM Method.



Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

Date : 03/28/2026
Project No : 2024C296
Client Company : Artisan
Arrival Time : 03/28/2026 08:00
Onsite Hours : 01:00

ASEC Report ID : 91898
Name of the Project : Heritage Pointe - Footing Inspections
Project Location : Villa Rica
Weather : Sunny
Departure Time : 03/28/2026 09:00
ASEC Technician Name : Sean Willett

PROCTOR DATA SUMMARY

TEST DATE	PROCTOR ID	MAX DRY DENSITY (pcf)	OPTIMUM MOISTURE (%)	PROCTOR TYPE	SOIL DESCRIPTION
03/28/2026	2026-077	95.8	20.0	Standard	Tan, brown Sandy SILT with clay