

Date : 04/30/2025
Project No : 2024C314
Client Company : Manhattan Const.
Arrival Time : 04/30/2025 12:30
Onsite Hours : 04:00

ASEC Report ID : 81377
Name of the Project : Concourse B Grease Receptors
Project Location : HJAIA
Weather : sunny
Departure Time : 04/30/2025 16:30
ASEC Technician Name : Aminullah Azimi

As requested, a representative from AS Engineering and Consulting (ASEC) visited the site to perform quality control inspection and testing services. Visual observation techniques were employed to verify compliance with project drawings/specifications, applicable codes, and approved material submittals. The following observations were made during the site visit:

The placement of 3 cubic yards of 3000 psi concrete for B9-Co-1 (proposed cleanout) was performed (location shown in the picture).

Concrete observed on this date appeared to be placed in compliance with project specifications with regard to temperature, air content, and batch to placement time.



Date : 04/30/2025
Project No : 2024C314
Client Company : Manhattan Const.
Arrival Time : 04/30/2025 12:30
Onsite Hours : 04:00

ASEC Report ID : 81377
Name of the Project : Concourse B Grease Receptors
Project Location : HJAIA
Weather : sunny
Departure Time : 04/30/2025 16:30
ASEC Technician Name : Aminullah Azimi



Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.