

Date : 05/01/2025
 Project No : 2024C314
 Client Company : Manhattan Const.
 Arrival Time : 05/01/2025 7:00
 Onsite Hours : 11:00

ASEC Report ID : 81368
 Name of the Project : Concourse B Grease Receptors
 Project Location : HJAIA
 Weather : sunny
 Departure Time : 05/01/2025 18:00
 ASEC Technician Name : Aminullah Azimi

Test Date	Test Number	Moisture Content (%)	Dry Density (pcf)	Proctor Number	Max. Dry Density (pcf)	Optimum Moisture (%)	Compaction (%)	Specified Compaction (%)	ASTM Test Method	Pass/Fail
05/01/2025	1	4.4	135.4	GAB	135.6	6.8	95.6	95	D6938	Pass
Location : Perimeter of grease traps around sewer MH-1, Elv/Depth :at finished grade Comment : Tested By : Aminullah Azimi Gauge Serial No. : 85759										

Remark: Test performed in general accordance with signed referenced ASTM Method.



Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

Date : 05/01/2025
Project No : 2024C314
Client Company : Manhattan Const.
Arrival Time : 05/01/2025 7:00
Onsite Hours : 11:00

ASEC Report ID : 81368
Name of the Project : Concourse B Grease Receptors
Project Location : HJAIA
Weather : sunny
Departure Time : 05/01/2025 18:00
ASEC Technician Name : Aminullah Azimi

PROCTOR DATA SUMMARY

TEST DATE	PROCTOR ID	MAX DRY DENSITY (pcf)	OPTIMUM MOISTURE (%)	PROCTOR TYPE	SOIL DESCRIPTION
05/01/2022	GAB	135.6	6.8	Modified	Graded Aggregate Base