

Date : 05/22/2025
Project No : 2024C314
Client Company : Manhattan Const.
Arrival Time : 05/21/2025 23:45
Onsite Hours : 05:45

ASEC Report ID : 81819
Name of the Project : Concourse B Grease Receptors
Project Location : HJAIA
Weather :
Departure Time : 05/22/2025 05:30
ASEC Technician Name : Solomon Cherie

Location(S):

Testing: 1 Set of concrete specimens (7 Cylinders per set) were cast during the cast-in-place concrete pour at the above referenced location, in accordance with ASTM C31. The cylinders will remain on site for the initial 24-48 hrs curing.

Compliance: ☒ Field placement of concrete appeared to be in general accordance with the project specifications (i.e., slump, temperature, etc) (refer to remarks below)
☐ Deviations and/or noncompliances were noted during the field placement (refer to remarks below)

Cylinders Pick Up: 1 Sets of concrete cylinders/ 7 cylinders per set were picked up & transported to AS Engineering and Consulting LLC (ASEC) for curing and testing in accordance with ASTM C39, C670/1231

Field Curing: Cylinders were stored for the initial 24 hours
☒ Near the poured structure
☐ In an insulated curing box
☐ Other

Remarks: One set of seven beams of concrete was casted after taking slump, temperature, air and unit weight tests.

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.