

Date : 05/22/2025
Project No : 2024C314
Client Company : Manhattan Const.
Arrival Time : 05/21/2025 23:45
Onsite Hours : 05:45

ASEC Report ID : 81817
Name of the Project : Concourse B Grease Receptors
Project Location : HJAIA
Weather :
Departure Time : 05/22/2025 05:30
ASEC Technician Name : Solomon Cherie

A concrete pouring at concourse B Grease Trap was placed. It is 45 yards.

Slump, air, temperature and unit weight tests were done and is according to the mix design. Moreover seven beams of concrete sample was casted.



Picture depicting concrete pouring location at Grease Trap

Kenneth Mosman

Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.