

Date : 03/12/2025
Project No : 2024C315
Client Company : J. Chapman Const.
Arrival Time : 03/12/2025 10:30
Onsite Hours : 02:00

ASEC Report ID : 78682
Name of the Project : Cottages at Villa Rica - Rock Blasting
Project Location : Villa Rica
Weather : Sunny
Departure Time : 03/12/2025 12:30
ASEC Technician Name : Micah Aycock

Site Visit Report - Cottages at Villa Rica

An AS Engineering and Consulting (ASEC) representative visited the Cottages at Villa Rica site to monitor drilling and rock removal operations. The contractor performing the work was Precision Blasting. The following observations were made on-site:

Blasting Data:

Blasting operations took place today in the northeast corner of the development between Lot #53 and Lot #54 using a mass rock pattern. The total blasted area was 1,944 square feet, with a calculated rock volume of 477.36 cubic yards. The average hole depth was 6.63 feet.

These efforts are part of Precision Blasting's ongoing work to break up the small trench rock section in the northwest corner of the Cottages at Villa Rica.

We appreciate the opportunity to assist with this project. Should you have any questions regarding this report, please do not hesitate to contact us. We would be happy to discuss any details further.



Lot #53/54



Date : 03/12/2025
Project No : 2024C315
Client Company : J. Chapman Const.
Arrival Time : 03/12/2025 10:30
Onsite Hours : 02:00

ASEC Report ID : 78682
Name of the Project : Cottages at Villa Rica - Rock Blasting
Project Location : Villa Rica
Weather : Sunny
Departure Time : 03/12/2025 12:30
ASEC Technician Name : Micah Aycock



Ramchandra R. Mogulla
GA P.E. 036021
Senior Engineer

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.