

Date : 03/29/2025  
 Project No : 2025C146  
 Client Company : Davidson Homes, LLC  
 Arrival Time : 03/29/2025 9:30  
 Onsite Hours : 07:00

ASEC Report ID : 80069  
 Name of the Project : Greene Farms Subdivision  
 Project Location : 1451 Highway 113, Cartersville, Georgia  
 Weather : sunny  
 Departure Time : 03/29/2025 16:30  
 ASEC Technician Name : Aminullah Azimi

Test Date	Test Number	Moisture Content (%)	Dry Density (pcf)	Proctor Number	Max. Dry Density (pcf)	Optimum Moisture (%)	Compaction (%)	Specified Compaction (%)	ASTM Test Method	Pass/Fail
03/29/2025	1	17.1	127.0	ASECP003	109.2	18.5	99.4	95	D6938	Pass
Location : road (location as shown in daily report), Elv/Depth :0.5 foot below finished grade										
Comment :										
Tested By : Aminullah Azimi Gauge Serial No. : 85759										
03/29/2025	2	16.9	109.0	ASECP003	109.2	18.5	99.8	95	D6938	Pass
Location : road (location is shown in daily report), Elv/Depth :0.5 foot below finished grade										
Comment :										
Tested By : Aminullah Azimi Gauge Serial No. : 85759										
03/29/2025	3	17.1	126.1	ASECP003	109.2	18.5	98.6	95	D6938	Pass
Location : road (location is shown in daily report), Elv/Depth :0.5 foot below finished grade										
Comment :										
Tested By : Aminullah Azimi Gauge Serial No. : 85759										

**Remark:** Test performed in general accordance with signed referenced ASTM Method.



**Kenneth Mosman**

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

Date : 03/29/2025  
 Project No : 2025C146  
 Client Company : Davidson Homes, LLC  
 Arrival Time : 03/29/2025 9:30  
 Onsite Hours : 07:00

ASEC Report ID : 80069  
 Name of the Project : Greene Farms Subdivision  
 Project Location : 1451 Highway 113, Cartersville, Georgia  
 Weather : sunny  
 Departure Time : 03/29/2025 16:30  
 ASEC Technician Name : Aminullah Azimi

**PROCTOR DATA SUMMARY**

TEST DATE	PROCTOR ID	MAX DRY DENSITY (pcf)	OPTIMUM MOISTURE (%)	PROCTOR TYPE	SOIL DESCRIPTION
03/05/2025	ASECP002	99.4	22.4	Standard	Light brown, Sandy CLAY with silt
03/06/2025	ASECP003	109.2	18.5	Standard	Light brown Silty SAND with some topsoil
03/11/2025	ASECP004	115.0	12.0	Standard	Light brown Clayey SAND
03/12/2025	ASECP005	106.8	16.5	Standard	Light brown Clayey SAND
04/11/2025	2025-16 SP	108.9	17.7	Standard	Red Silty SAND