

Date : 04/22/2025  
 Project No : 2025C149  
 Client Company : Davidson Homes  
 Arrival Time : 04/22/2025 8:30  
 Onsite Hours : 07:00

ASEC Report ID : 81661  
 Name of the Project : Grove at E. Thompson Mill Rd  
 Project Location : Buford  
 Weather : sunny  
 Departure Time : 04/22/2025 15:30  
 ASEC Technician Name : Aminullah Azimi

Test Date	Test Number	Moisture Content (%)	Dry Density (pcf)	Proctor Number	Max. Dry Density (pcf)	Optimum Moisture (%)	Compaction (%)	Specified Compaction (%)	ASTM Test Method	Pass/Fail
04/22/2025	1	25.2	94.3	2025-022 SP	103.7	16.1	90.9	90	D6938	Pass
Location : pond 1-perimeter , Elv/Depth :11.5 feet below finished grade Comment : Tested By : Aminullah Azimi Gauge Serial No. : 85759										
04/22/2025	2	25.5	95.7	2025-023 SP	103.5	18.9	92.5	90	D6938	Pass
Location : pond -1 perimeter, Elv/Depth :11.5 feet below finished grade Comment : Tested By : Aminullah Azimi Gauge Serial No. : 85759										
04/22/2025	3	25.3	94.4	2025-023 SP	103.5	18.9	91.2	90	D6938	Pass
Location : pond-1 perimeter , Elv/Depth :11 feet below finished grade Comment : Tested By : Aminullah Azimi Gauge Serial No. : 85759										
04/22/2025	4	22.1	96.6	2025-023 SP	103.5	18.9	93.3	90	D6938	Pass
Location : pond-1 perimeter , Elv/Depth :11 feet below finished grade Comment : Tested By : Aminullah Azimi Gauge Serial No. : 85759										

**Remark:** Test performed in general accordance with signed referenced ASTM Method.



**Kenneth Mosman**

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

Date : 04/22/2025  
 Project No : 2025C149  
 Client Company : Davidson Homes  
 Arrival Time : 04/22/2025 8:30  
 Onsite Hours : 07:00

ASEC Report ID : 81661  
 Name of the Project : Grove at E. Thompson Mill Rd  
 Project Location : Buford  
 Weather : sunny  
 Departure Time : 04/22/2025 15:30  
 ASEC Technician Name : Aminullah Azimi

**PROCTOR DATA SUMMARY**

TEST DATE	PROCTOR ID	MAX DRY DENSITY (pcf)	OPTIMUM MOISTURE (%)	PROCTOR TYPE	SOIL DESCRIPTION
04/22/2025	2025-022 SP	103.7	16.1	Standard	Brown Sandy SILT
04/22/2025	2025-023 SP	103.5	18.9	Standard	Red Sandy CLAY