

Date : 05/06/2025  
Project No : 2025C150  
Client Company : Davidson Homes  
Arrival Time : 05/06/2025 08:00  
Onsite Hours : 08:00

---

As requested, the site was visited by our AS Engineering and Consulting (ASEC) representative for the purpose of providing quality control inspection and testing services. Visual observation techniques were employed to verify compliance with project drawing/specifications, applicable codes, and materials submittals. The following observations were observed on site this day.

Following up on the progress from the previous day, work has continued behind Lots #224 to #229. The contractor has made progress in the preparation of the retaining wall foundation and the Lots #224 through #229.

Backfilling and compaction activities were performed within Lots #224 to #229. The contractor utilized a Kobelco 310LC excavator to place the fill material in designated areas. Following placement, the material was transported and uniformly distributed across the lots using a Bobcat 265 and Takeuchi TL12R2 compact track loaders. Once the fill was spread, compaction operations commenced using a Bomag BW211 sheeps-foot roller.

Nuclear gauge density testing was performed near each individual lot and also adjacent to the retaining wall to evaluate moisture content and dry density. The results showed compaction levels exceeding 95% in some locations but falling short in others. Based on this data, the superintendent was advised to dedicate additional time to compaction in areas with insufficient density. After re-compaction, general probing and proof-rolling tests were performed. No severe deflections were noted.

Upon successful compaction of the lift, the contractor advanced to the next layer of backfill. This subsequent layer underwent the same testing and quality control process. Both general probing and proof-rolling tests verified stability of surficial soils. Near the wall the compaction was carried out with a remote compactor BMP8500 for compaction along the retaining wall.

We appreciate the opportunity to be of service to you on this project. If you have any questions regarding this report, please feel free to contact us. We will be more than happy to discuss it with you.

ASEC Report ID : 81463  
Name of the Project : Riverwood Retaining Wall  
Project Location : Dallas  
Weather : partly cloudy  
Departure Time : 05/06/2025 16:00  
ASEC Technician Name : Vamsi Polisetty

Date : 05/06/2025  
Project No : 2025C150  
Client Company : Davidson Homes  
Arrival Time : 05/06/2025 08:00  
Onsite Hours : 08:00



ASEC Report ID : 81463  
Name of the Project : Riverwood Retaining Wall  
Project Location : Dallas  
Weather : partly cloudy  
Departure Time : 05/06/2025 16:00  
ASEC Technician Name : Vamsi Polisetty

Date : 05/06/2025  
Project No : 2025C150  
Client Company : Davidson Homes  
Arrival Time : 05/06/2025 08:00  
Onsite Hours : 08:00



ASEC Report ID : 81463  
Name of the Project : Riverwood Retaining Wall  
Project Location : Dallas  
Weather : partly cloudy  
Departure Time : 05/06/2025 16:00  
ASEC Technician Name : Vamsi Polisetty

Date : 05/06/2025  
Project No : 2025C150  
Client Company : Davidson Homes  
Arrival Time : 05/06/2025 08:00  
Onsite Hours : 08:00



Date : 05/06/2025  
Project No : 2025C150  
Client Company : Davidson Homes  
Arrival Time : 05/06/2025 08:00  
Onsite Hours : 08:00



ASEC Report ID : 81463  
Name of the Project : Riverwood Retaining Wall  
Project Location : Dallas  
Weather : partly cloudy  
Departure Time : 05/06/2025 16:00  
ASEC Technician Name : Vamsi Polisetty

Date : 05/06/2025  
Project No : 2025C150  
Client Company : Davidson Homes  
Arrival Time : 05/06/2025 08:00  
Onsite Hours : 08:00



Date : 05/06/2025  
Project No : 2025C150  
Client Company : Davidson Homes  
Arrival Time : 05/06/2025 08:00  
Onsite Hours : 08:00



ASEC Report ID : 81463  
Name of the Project : Riverwood Retaining Wall  
Project Location : Dallas  
Weather : partly cloudy  
Departure Time : 05/06/2025 16:00  
ASEC Technician Name : Vamsi Polisetty

Date : 05/06/2025  
Project No : 2025C150  
Client Company : Davidson Homes  
Arrival Time : 05/06/2025 08:00  
Onsite Hours : 08:00

---



**Kenneth Mosman**

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.