

Date : 03/27/2025
 Project No : 2025C160
 Client Company : Artisan
 Arrival Time : 03/27/2025 9:00
 Onsite Hours : 07:30

ASEC Report ID : 80058
 Name of the Project : Rockmart Township - 115 Felton Drive
 Project Location : Rockmart
 Weather : sunny
 Departure Time : 03/27/2025 16:30
 ASEC Technician Name : Aminullah Azimi

Test Date	Test Number	Moisture Content (%)	Dry Density (pcf)	Proctor Number	Max. Dry Density (pcf)	Optimum Moisture (%)	Compaction (%)	Specified Compaction (%)	ASTM Test Method	Pass/Fail
03/27/2025	1	17.4	112.8	2025-008 SP	115.7	14.7	97.5	95	D6938	Pass
Location : Lot #137, Elv/Depth :5 feet below finished grade										
Comment :										
Tested By : Aminullah Azimi Gauge Serial No. : 85759										
03/27/2025	2	16.5	111.0	2025-008 SP	115.7	14.7	95.9	95	D6938	Pass
Location : Lot #138, Elv/Depth :5 feet below finished grade										
Comment : need proctor for result										
Tested By : Aminullah Azimi Gauge Serial No. : 85759										
03/27/2025	3	17.2	111.0	2025-008 SP	115.7	14.7	95.9	95	D6938	Pass
Location : Lot #139, Elv/Depth :5 feet below finished grade										
Comment :										
Tested By : Aminullah Azimi Gauge Serial No. : 85759										

Remark: Test performed in general accordance with signed referenced ASTM Method.



Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

Date : 03/27/2025
 Project No : 2025C160
 Client Company : Artisan
 Arrival Time : 03/27/2025 9:00
 Onsite Hours : 07:30

ASEC Report ID : 80058
 Name of the Project : Rockmart Township - 115 Felton Drive
 Project Location : Rockmart
 Weather : sunny
 Departure Time : 03/27/2025 16:30
 ASEC Technician Name : Aminullah Azimi

PROCTOR DATA SUMMARY

TEST DATE	PROCTOR ID	MAX DRY DENSITY (pcf)	OPTIMUM MOISTURE (%)	PROCTOR TYPE	SOIL DESCRIPTION
03/27/2025	2025-008 SP	115.7	14.7	Standard	Brown Silty SAND with clay
03/27/2025	2025-011 SP	115.0	15.5	Standard	Brown Silty SAND with clay
03/28/2025	2025-012 SP	105.6	18.9	Standard	Brown Sandy CLAY