

Date : 04/18/2025
Project No : 2025C160
Client Company : Artisan
Arrival Time : 04/18/2025 08:30
Onsite Hours : 06:00

ASEC Report ID : 80091
Name of the Project : Rockmart Township - 115 Felton Drive
Project Location : Rockmart
Weather : Sunny
Departure Time : 04/18/2025 14:30
ASEC Technician Name : Sean Willett

As requested, the site was visited by our AS Engineering and Consulting (ASEC) representative for the purpose of providing quality control inspection and testing services. Visual observation techniques were employed to verify compliance with project drawing/specifications, applicable codes, and materials submittals. The following observations were observed on site this day.

Our ASEC representative was on site as requested by the contractor (Wilbanks) for the observation of the placement of fill in approximately 8-inch lifts and compact fill around SSMH1.0A and SSMH1.0B. The technician tested the compaction until using a nuclear density gauge. The technician observed the contractor excavate a trench to SSMH2.0 with an excavation of approximately 4 feet filled with approximately 3.5 feet of rip rap and approximately a 1-foot cap of No. 57 stone.

We appreciate the opportunity to be of service to you on this project. If you have any questions regarding this report, please feel free to contact us. We will be more than happy to discuss it with you.



water management in trench to SSMH2.0



compaction SSMH1.0A and SSMH1.0B

Date : 04/18/2025
Project No : 2025C160
Client Company : Artisan
Arrival Time : 04/18/2025 08:30
Onsite Hours : 06:00

ASEC Report ID : 80091
Name of the Project : Rockmart Township - 115 Felton Drive
Project Location : Rockmart
Weather : Sunny
Departure Time : 04/18/2025 14:30
ASEC Technician Name : Sean Willett



compaction to SSMH2.0



SSMH 1.0A and SSMH 1.0B compaction



trench to SSMH2.0



fill and compaction around SSMH1.0 A and SSMH1.0B

Date : 04/18/2025
Project No : 2025C160
Client Company : Artisan
Arrival Time : 04/18/2025 08:30
Onsite Hours : 06:00

ASEC Report ID : 80091
Name of the Project : Rockmart Township - 115 Felton Drive
Project Location : Rockmart
Weather : Sunny
Departure Time : 04/18/2025 14:30
ASEC Technician Name : Sean Willett



compaction SSMH1.0A



Kenneth Mosman

Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.